

**Part III Form 2
Section 11. ANNUAL REPORT.**

Drinking-Water System Number:	260001929
Drinking-Water System Name:	York Water System
Drinking-Water System Owner:	Regional Municipality of York
Drinking-Water System Category:	Large Municipal Residential receiving from Large Municipal Residential
Period being reported:	January 1, 2007 to December 31, 2007

<p><u>Complete if your Category is Large Municipal Residential or Small Municipal Residential</u></p> <p>Does your Drinking-Water System serve more than 10,000 people? Yes [X] No []</p> <p>Is your annual report available to the public at no charge on a web site on the Internet? Yes [X] No []</p> <p>Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.</p> <div style="border: 1px solid black; padding: 5px;"> Regional Municipality of York Administrative Building Transportation and Works Department 17250 Yonge Street Newmarket, Ontario </div>	<p><u>Complete for all other Categories.</u></p> <p>Number of Designated Facilities served: <input style="width: 100px; height: 20px;" type="text"/></p> <p>Did you provide a copy of your annual report to all Designated Facilities you serve? Yes [] No []</p> <p>Number of Interested Authorities you report to: <input style="width: 100px; height: 20px;" type="text"/></p> <p>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? Yes [] No []</p>
--	--

Note: For the following tables below, additional rows or columns may be added or an appendix may be attached to the report

List all Drinking-Water Systems (if any), which receive all of their drinking water from your system:

Drinking Water System Name	Drinking Water System Number
Markham Distribution System	220004162
Richmond Hill Distribution System	260001968
Vaughan Distribution System	260003097
Town of Aurora, Aurora Distribution System	260003227

Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water?

Yes No

Indicate how you notified system users that your annual report is available, and is free of charge.

Public access/notice via the web

Public access/notice via Government Office

Public access/notice via a newspaper

Public access/notice via Public Request

Public access/notice via a Public Library

Public access/notice via other method _____

Describe your Drinking-Water System

The urban areas of Markham, Richmond Hill and Vaughan in York Region receive their water supply from the City of Toronto Water Treatment Plants. The York Water System began receiving water from Peel Region in October 2005. Parts of Aurora only receive a small portion of their water supply through Toronto based water.

York Region owns and operates pumping stations, storage facilities and large diameter watermains required to transmit water between pumping stations and storage facilities. Markham, Richmond Hill, Vaughan and Aurora each own and operate the smaller watermains including fire hydrants and service connections which form their distribution systems.

List all water treatment chemicals used over this reporting period

--

Were any significant expenses incurred to?

Install required equipment

Repair required equipment

Replace required equipment

Please provide a brief description and a breakdown of monetary expenses incurred

Some of the following expenditures represent only part of the total project costs.

--

Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre

Incident Date	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date

Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.

	Number of Samples	Range of E.Coli Or Fecal Results (min #)-(max #)	Range of Total Coliform Results (min #)-(max #)	Number of HPC Samples	Range of HPC Results (min #)-(max #)
Raw					
Treated					
Distribution	933	0	0	473	0-12

Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.

	Number of Grab Samples	Range of Results (min #)-(max #)
Turbidity		
Chlorine	1146	0.46-1.49
Fluoride (If the DWS provides fluoridation)		

NOTE: For continuous monitors use 8760 as the number of samples.

NOTE: Record the unit of measure if it is not milligrams per litre.

Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument.

Date of legal instrument issued	Parameter	Date Sampled	Result	Unit of Measure

Summary of Inorganic parameters tested during this reporting period or the most recent sample results

NOTE: see attached results for Inorganic parameters

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony				
Arsenic				

Barium				
Boron				
Cadmium				
Chromium				
Lead				
Mercury				
Selenium				
Sodium				
Uranium				
Fluoride				
Nitrite				
Nitrate				

Summary of Organic parameters sampled during this reporting period or the most recent sample results

NOTE: see attached results for Organic parameters (THM values in table below).

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor				
Aldicarb				
Aldrin + Dieldrin				
Atrazine + N-dealkylated metabolites				
Azinphos-methyl				
Bendiocarb				
Benzene				
Benzo(a)pyrene				
Bromoxynil				
Carbaryl				
Carbofuran				
Carbon Tetrachloride				
Chlordane (Total)				
Chlorpyrifos				
Cyanazine				
Diazinon				
Dicamba				
1,2-Dichlorobenzene				
1,4-Dichlorobenzene				
Dichlorodiphenyltrichloroethane (DDT) + metabolites				
1,2-Dichloroethane				
1,1-Dichloroethylene (vinylidene chloride)				
Dichloromethane				

2-4 Dichlorophenol				
2,4-Dichlorophenoxy acetic acid (2,4-D)				
Diclofop-methyl				
Dimethoate				
Dinoseb				
Diquat				
Diuron				
Glyphosate				
Heptachlor + Heptachlor Epoxide				
Lindane (Total)				
Malathion				
Methoxychlor				
Metolachlor				
Metribuzin				
Monochlorobenzene				
Paraquat				
Parathion				
Pentachlorophenol				
Phorate				
Picloram				
Polychlorinated Biphenyls(PCB)				
Prometryne				
Simazine				
THM (NOTE: show latest annual average)	E Woodbridge Elevated Tank	0.0158	Mg/L	
	Jefferson Reservoir	0.018	Mg/L	
	Markham Elevated Tank	0.015	Mg/L	
	Markham Reservoir	0.0153	Mg/L	
	Miliken Elevated Tank	0.0148	Mg/L	
	North Maple Reservoir	0.023	Mg/L	
	North Richmond Hill Reservoir	0.0178	Mg/L	
	Oak Ridges Standpipe	0.0193	Mg/L	
	South Maple Reservoir	0.0215	Mg/L	
	South Richmond Hill Reservoir	0.0185	Mg/L	
	West Woodbridge Elevated Tank	0.017	Mg/L	
Temephos				

Terbufos				
Tetrachloroethylene				
2,3,4,6-Tetrachlorophenol				
Triallate				
Trichloroethylene				
2,4,6-Trichlorophenol				
2,4,5-Trichlorophenoxy acetic acid (2,4,5-T)				
Trifluralin				
Vinyl Chloride				

York Region monitors another group of disinfection by-products called haloacetic acids (HAAs). There are no limits set for HAAs in Ontario Drinking Water Standards.

Reading Name	S Maple Reservoir Mg/L Oct 22	Sutton Tower Mg/L Oct 22
Bromochloroacetic acid	< 0.004	< 0.004
Dibromoacetic acid	< 0.004	< 0.004
Dichloroacetic acid	0.005	< 0.004
Monobromoacetic acid	< 0.004	< 0.004
Monochloroacetic acid	< 0.035	< 0.035
Trichloroacetic acid	0.007	0.004

“<” indicates the result is below the Method Detection Limit

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

Parameter	Result Value	Unit of Measure	Date of Sample

(Only if DWS category is large municipal residential, small municipal residential, large municipal non residential, non municipal year round residential, large non municipal non residential)



Inorganics Test Results

Reading	Units	ODWS		22/01/2007	16/04/2007	09/07/2007	22/10/2007
Antimony as Sb	mg/L	0.006	IMAC	< 0.0004	< 0.0004	< 0.0004	0.0007
Arsenic as As	mg/L	0.025	IMAC	< 0.0004	< 0.0004	< 0.0004	0.0016
Barium as Ba	mg/L	1	MAC				0.0268
Boron as B	mg/L	5	IMAC				0.0271
Cadmium as Cd	mg/L	0.005	MAC	< 0.0001	< 0.0001	< 0.0001	< 0.0001
Chromium as Cr	mg/L	0.05	MAC	< 0.0003	0.0004	< 0.0003	< 0.0003
Fluoride as F	mg/L	0.8	MAC	0.58	0.55	0.58	0.6
Lead as Pb	mg/L	0.01	MAC	< 0.0007	< 0.0007	< 0.0007	< 0.0007
Mercury as Hg	mg/L	0.001	MAC				< 0.00001
Nitrate as N	mg/L	10	MAC	0.54	0.52	0.46	0.45
Nitrite	mg/L	1	MAC	< 0.02	< 0.02	< 0.02	< 0.002
Selenium as Se	mg/L	0.01	MAC	< 0.002	< 0.002	< 0.002	< 0.002
Sodium as Na	mg/L	200	AO	14.4	17.2	13.7	13.4
Uranium as U	mg/L	0.02	MAC				< 0.002

"<": indicates the result is below Method Detection Limit
 ODWS: Ontario Drinking Water Standard
 MAC: Ontario Drinking Water Standard - Health Related (Maximum Acceptable Concentration)
 AO: Ontario Drinking Water Standard - Non Health Related (Aesthetic Objective)
 mg/L: milligrams per litre, parts permillion (ppm)



Inorganics Test Results

Reading	Units	ODWS		22/01/2007	16/04/2007	09/07/2007	22/10/2007
Antimony as Sb	mg/L	0.006	IMAC	< 0.0004	< 0.0004	< 0.0004	0.0008
Arsenic as As	mg/L	0.025	IMAC	< 0.0004	< 0.0004	< 0.0004	0.0008
Barium as Ba	mg/L	1	MAC				0.0268
Boron as B	mg/L	5	IMAC				0.0264
Cadmium as Cd	mg/L	0.005	MAC	< 0.0001	< 0.0001	0.0001	< 0.0001
Chromium as Cr	mg/L	0.05	MAC	< 0.0003	< 0.0003	< 0.0003	< 0.0003
Fluoride as F	mg/L	0.8	MAC	0.58	0.56	0.59	0.59
Lead as Pb	mg/L	0.01	MAC	< 0.0007	< 0.0007	< 0.0007	< 0.0007
Mercury as Hg	mg/L	0.001	MAC				< 0.00001
Nitrate as N	mg/L	10	MAC	0.56	0.54	0.44	0.36
Nitrite	mg/L	1	MAC	< 0.02	< 0.02	< 0.02	0.006
Selenium as Se	mg/L	0.01	MAC	< 0.002	< 0.002	0.003	< 0.002
Sodium as Na	mg/L	200	AO	14.9	18.1	13.9	13.1
Uranium as U	mg/L	0.02	MAC				< 0.002

"<": indicates the result is below Method Detection Limit
 ODWS: Ontario Drinking Water Standard
 MAC: Ontario Drinking Water Standard - Health Related (Maximum Acceptable Concentration)
 AO: Ontario Drinking Water Standard - Non Health Related (Aesthetic Objective)
 mg/L: milligrams per litre, parts permillion (ppm)



Inorganics Test Results

Reading	Units	ODWS		22/01/2007	16/04/2007	09/07/2007	22/10/2007
Antimony as Sb	mg/L	0.006	IMAC	< 0.0004	< 0.0004	< 0.0004	0.0008
Arsenic as As	mg/L	0.025	IMAC	< 0.0004	< 0.0004	< 0.0004	0.0011
Barium as Ba	mg/L	1	MAC				0.0272
Boron as B	mg/L	5	IMAC				0.028
Cadmium as Cd	mg/L	0.005	MAC	< 0.0001	< 0.0001	< 0.0001	< 0.0001
Chromium as Cr	mg/L	0.05	MAC	< 0.0003	< 0.0003	< 0.0003	< 0.0003
Fluoride as F	mg/L	0.8	MAC	0.58	0.57	0.59	0.6
Lead as Pb	mg/L	0.01	MAC	< 0.0007	< 0.0007	< 0.0007	< 0.0007
Mercury as Hg	mg/L	0.001	MAC				< 0.00001
Nitrate as N	mg/L	10	MAC	0.53	0.48	0.48	0.45
Nitrite	mg/L	1	MAC	< 0.02	< 0.02	< 0.02	0.005
Selenium as Se	mg/L	0.01	MAC	< 0.002	< 0.002	< 0.002	< 0.002
Sodium as Na	mg/L	200	AO	14.1	16.2	13.8	13.5
Uranium as U	mg/L	0.02	MAC				< 0.002

"<": indicates the result is below Method Detection Limit
 ODWS: Ontario Drinking Water Standard
 MAC: Ontario Drinking Water Standard - Health Related (Maximum Acceptable Concentration)
 AO: Ontario Drinking Water Standard - Non Health Related (Aesthetic Objective)
 mg/L: milligrams per litre, parts permillion (ppm)



Inorganics Test Results

Reading	Units	ODWS		22/01/2007	16/04/2007	09/07/2007	22/10/2007
Antimony as Sb	mg/L	0.006	IMAC	< 0.0004	< 0.0004	< 0.0004	0.0007
Arsenic as As	mg/L	0.025	IMAC	< 0.0004	< 0.0004	< 0.0004	0.0007
Barium as Ba	mg/L	1	MAC				0.0261
Boron as B	mg/L	5	IMAC				0.0272
Cadmium as Cd	mg/L	0.005	MAC	< 0.0001	< 0.0001	< 0.0001	< 0.0001
Chromium as Cr	mg/L	0.05	MAC	< 0.0003	< 0.0003	0.0006	< 0.0003
Fluoride as F	mg/L	0.8	MAC	0.58	0.64	0.57	0.57
Lead as Pb	mg/L	0.01	MAC	< 0.0007	< 0.0007	< 0.0007	< 0.0007
Mercury as Hg	mg/L	0.001	MAC				< 0.00001
Nitrate as N	mg/L	10	MAC	0.57	0.49	0.49	0.46
Nitrite	mg/L	1	MAC	< 0.02	< 0.02	< 0.02	0.01
Selenium as Se	mg/L	0.01	MAC	< 0.002	< 0.002	< 0.002	< 0.002
Sodium as Na	mg/L	200	AO	14	14.5	12.9	12.8
Uranium as U	mg/L	0.02	MAC				< 0.002

"<": indicates the result is below Method Detection Limit
 ODWS: Ontario Drinking Water Standard
 MAC: Ontario Drinking Water Standard - Health Related (Maximum Acceptable Concentration)
 AO: Ontario Drinking Water Standard - Non Health Related (Aesthetic Objective)
 mg/L: milligrams per litre, parts permillion (ppm)



Inorganics Test Results

Reading	Units	ODWS		22/01/2007	16/04/2007	09/07/2007	22/10/2007
Antimony as Sb	mg/L	0.006	IMAC	< 0.0004	< 0.0004	< 0.0004	0.0009
Arsenic as As	mg/L	0.025	IMAC	< 0.0004	< 0.0004	< 0.0004	< 0.0007
Barium as Ba	mg/L	1	MAC				0.0264
Boron as B	mg/L	5	IMAC				0.0276
Cadmium as Cd	mg/L	0.005	MAC	< 0.0001	< 0.0001	< 0.0001	< 0.0001
Chromium as Cr	mg/L	0.05	MAC	< 0.0003	< 0.0003	0.0008	< 0.0003
Fluoride as F	mg/L	0.8	MAC	0.59	0.7	0.58	0.58
Lead as Pb	mg/L	0.01	MAC	0.001	< 0.0007	< 0.0007	< 0.0007
Mercury as Hg	mg/L	0.001	MAC				< 0.00001
Nitrate as N	mg/L	10	MAC	0.52	0.45	0.48	0.41
Nitrite	mg/L	1	MAC	< 0.02	< 0.02	< 0.02	0.01
Selenium as Se	mg/L	0.01	MAC	< 0.002	< 0.002	< 0.002	< 0.002
Sodium as Na	mg/L	200	AO	13.9	14.5	13	12.9
Uranium as U	mg/L	0.02	MAC				< 0.002

"<": indicates the result is below Method Detection Limit
 ODWS: Ontario Drinking Water Standard
 MAC: Ontario Drinking Water Standard - Health Related (Maximum Acceptable Concentration)
 AO: Ontario Drinking Water Standard - Non Health Related (Aesthetic Objective)
 mg/L: milligrams per litre, parts permillion (ppm)



Inorganics Test Results

Reading	Units	ODWS		22/01/2007	16/04/2007	09/07/2007	22/10/2007
Antimony as Sb	mg/L	0.006	IMAC	< 0.0004	< 0.0004	< 0.0004	0.0007
Arsenic as As	mg/L	0.025	IMAC	< 0.0004	< 0.0004	< 0.0004	0.0006
Barium as Ba	mg/L	1	MAC				0.0257
Boron as B	mg/L	5	IMAC				0.0269
Cadmium as Cd	mg/L	0.005	MAC	< 0.0001	< 0.0001	< 0.0001	< 0.0001
Chromium as Cr	mg/L	0.05	MAC	< 0.0003	0.0003	< 0.0003	0.001
Fluoride as F	mg/L	0.8	MAC	0.6	0.65	0.58	0.58
Lead as Pb	mg/L	0.01	MAC	< 0.0007	< 0.0007	< 0.0007	< 0.0007
Mercury as Hg	mg/L	0.001	MAC				< 0.00001
Nitrate as N	mg/L	10	MAC	0.53	0.47	0.49	0.44
Nitrite	mg/L	1	MAC	< 0.02	< 0.02	< 0.02	< 0.002
Selenium as Se	mg/L	0.01	MAC	< 0.002	< 0.002	< 0.002	< 0.002
Sodium as Na	mg/L	200	AO	14.8	14.4	13.1	12.8
Uranium as U	mg/L	0.02	MAC				< 0.002

"<": indicates the result is below Method Detection Limit
 ODWS: Ontario Drinking Water Standard
 MAC: Ontario Drinking Water Standard - Health Related (Maximum Acceptable Concentration)
 AO: Ontario Drinking Water Standard - Non Health Related (Aesthetic Objective)
 mg/L: milligrams per litre, parts permillion (ppm)



Inorganics Test Results

Reading	Units	ODWS		22/01/2007	16/04/2007	09/07/2007	22/10/2007
Antimony as Sb	mg/L	0.006	IMAC	< 0.0004	< 0.0004	< 0.0004	0.0007
Arsenic as As	mg/L	0.025	IMAC	< 0.0004	< 0.0004	< 0.0004	0.0014
Barium as Ba	mg/L	1	MAC				0.0273
Boron as B	mg/L	5	IMAC				0.028
Cadmium as Cd	mg/L	0.005	MAC	< 0.0001	< 0.0001	< 0.0001	< 0.0001
Chromium as Cr	mg/L	0.05	MAC	< 0.0003	< 0.0003	< 0.0003	< 0.0003
Fluoride as F	mg/L	0.8	MAC	0.59	0.58	0.58	0.62
Lead as Pb	mg/L	0.01	MAC	< 0.0007	< 0.0007	< 0.0007	< 0.0007
Mercury as Hg	mg/L	0.001	MAC				< 0.00001
Nitrate as N	mg/L	10	MAC	0.53	0.52	0.5	0.39
Nitrite	mg/L	1	MAC	< 0.02	< 0.02	< 0.02	0.007
Selenium as Se	mg/L	0.01	MAC	< 0.002	< 0.002	0.003	< 0.002
Sodium as Na	mg/L	200	AO	14.6	18.6	14.5	14.7
Uranium as U	mg/L	0.02	MAC				< 0.002

"<": indicates the result is below Method Detection Limit
 ODWS: Ontario Drinking Water Standard
 MAC: Ontario Drinking Water Standard - Health Related (Maximum Acceptable Concentration)
 AO: Ontario Drinking Water Standard - Non Health Related (Aesthetic Objective)
 mg/L: milligrams per litre, parts permillion (ppm)



Inorganics Test Results

Reading	Units	ODWS		22/01/2007	16/04/2007	09/07/2007	22/10/2007
Antimony as Sb	mg/L	0.006	IMAC	< 0.0004	< 0.0004	< 0.0004	0.0007
Arsenic as As	mg/L	0.025	IMAC	< 0.0004	< 0.0004	< 0.0004	0.001
Barium as Ba	mg/L	1	MAC				0.0267
Boron as B	mg/L	5	IMAC				0.027
Cadmium as Cd	mg/L	0.005	MAC	< 0.0001	< 0.0001	< 0.0001	< 0.0001
Chromium as Cr	mg/L	0.05	MAC	< 0.0003	< 0.0003	< 0.0003	< 0.0003
Fluoride as F	mg/L	0.8	MAC	0.59	0.61	0.58	0.6
Lead as Pb	mg/L	0.01	MAC	< 0.0007	< 0.0007	< 0.0007	< 0.0007
Mercury as Hg	mg/L	0.001	MAC				< 0.00001
Nitrate as N	mg/L	10	MAC	0.52	0.5	0.46	0.42
Nitrite	mg/L	1	MAC	< 0.02	< 0.02	< 0.02	< 0.002
Selenium as Se	mg/L	0.01	MAC	< 0.002	< 0.002	0.003	< 0.002
Sodium as Na	mg/L	200	AO	14	15.8	13.5	13.5
Uranium as U	mg/L	0.02	MAC				< 0.002

"<": indicates the result is below Method Detection Limit
 ODWS: Ontario Drinking Water Standard
 MAC: Ontario Drinking Water Standard - Health Related (Maximum Acceptable Concentration)
 AO: Ontario Drinking Water Standard - Non Health Related (Aesthetic Objective)
 mg/L: milligrams per litre, parts permillion (ppm)



Inorganics Test Results

Reading	Units	ODWS		01/01/2007	25/04/2007	26/07/2007	17/10/2007
Antimony as Sb	mg/L	0.006	IMAC	< 0.0004	< 0.0004	< 0.0004	0.0006
Arsenic as As	mg/L	0.025	IMAC	< 0.0004	< 0.0004	< 0.0004	0.001
Cadmium as Cd	mg/L	0.005	MAC	< 0.0001	0.0001	< 0.0001	< 0.0001
Chromium as Cr	mg/L	0.05	MAC	< 0.0003	< 0.0003	< 0.0003	< 0.0003
Fluoride as F	mg/L	0.8	MAC	0.47	0.51	0.52	0.61
Lead as Pb	mg/L	0.01	MAC	< 0.0007	< 0.0007	< 0.0007	< 0.0007
Nitrate as N	mg/L	10	MAC	0.52	0.52	0.46	0.41
Nitrite	mg/L	1	MAC	< 0.02	< 0.02	< 0.02	0.01
Selenium as Se	mg/L	0.01	MAC	< 0.002	< 0.002	< 0.002	< 0.002
Sodium as Na	mg/L	200	AO	13.9	16.4	13.2	13.7

"<": indicates the result is below Method Detection Limit

ODWS: Ontario Drinking Water Standard

MAC: Ontario Drinking Water Standard - Health Related (Maximum Acceptable Concentration)

AO: Ontario Drinking Water Standard - Non Health Related (Aesthetic Objective)

mg/L: milligrams per litre, parts permillion (ppm)



Inorganics Test Results

Reading	Units	ODWS		22/01/2007	16/04/2007	09/07/2007	22/10/2007
Antimony as Sb	mg/L	0.006	IMAC	< 0.0004	< 0.0004	< 0.0004	0.0013
Arsenic as As	mg/L	0.025	IMAC	< 0.0004	< 0.0004	< 0.0004	0.0021
Barium as Ba	mg/L	1	MAC				0.0265
Boron as B	mg/L	5	IMAC				0.0266
Cadmium as Cd	mg/L	0.005	MAC	< 0.0001	< 0.0001	< 0.0001	< 0.0001
Chromium as Cr	mg/L	0.05	MAC	< 0.0003	0.0021	< 0.0003	< 0.0003
Fluoride as F	mg/L	0.8	MAC	0.57	0.6	0.61	0.55
Lead as Pb	mg/L	0.01	MAC	< 0.0007	< 0.0007	< 0.0007	< 0.0007
Mercury as Hg	mg/L	0.001	MAC				< 0.00001
Nitrate as N	mg/L	10	MAC	0.53	0.52	0.5	0.37
Nitrite	mg/L	1	MAC	< 0.02	< 0.02	< 0.02	< 0.002
Selenium as Se	mg/L	0.01	MAC	< 0.002	< 0.002	< 0.002	< 0.002
Sodium as Na	mg/L	200	AO	14.7	17.9	14.6	14.3
Uranium as U	mg/L	0.02	MAC				< 0.002

"<": indicates the result is below Method Detection Limit

ODWS: Ontario Drinking Water Standard

MAC: Ontario Drinking Water Standard - Health Related (Maximum Acceptable Concentration)

AO: Ontario Drinking Water Standard - Non Health Related (Aesthetic Objective)

mg/L: milligrams per litre, parts permillion (ppm)



Inorganics Test Results

Reading	Units	ODWS		22/01/2007	16/04/2007	09/07/2007	22/10/2007
Antimony as Sb	mg/L	0.006	IMAC	< 0.0004	< 0.0004	< 0.0004	0.0015
Arsenic as As	mg/L	0.025	IMAC	< 0.0004	< 0.0004	< 0.0004	< 0.0007
Barium as Ba	mg/L	1	MAC				0.0261
Boron as B	mg/L	5	IMAC				0.0266
Cadmium as Cd	mg/L	0.005	MAC	< 0.0001	< 0.0001	< 0.0001	< 0.0001
Chromium as Cr	mg/L	0.05	MAC	< 0.0003	< 0.0003	< 0.0003	< 0.0003
Fluoride as F	mg/L	0.8	MAC	0.58	0.56	0.59	0.57
Lead as Pb	mg/L	0.01	MAC	< 0.0007	< 0.0007	< 0.0007	< 0.0007
Mercury as Hg	mg/L	0.001	MAC				< 0.00001
Nitrate as N	mg/L	10	MAC	0.54	0.56	0.51	0.43
Nitrite	mg/L	1	MAC	< 0.02	< 0.02	< 0.02	< 0.002
Selenium as Se	mg/L	0.01	MAC	< 0.002	< 0.002	< 0.002	< 0.002
Sodium as Na	mg/L	200	AO	14.9	17.8	13.8	12.9
Uranium as U	mg/L	0.02	MAC				< 0.002

"<": indicates the result is below Method Detection Limit
 ODWS: Ontario Drinking Water Standard
 MAC: Ontario Drinking Water Standard - Health Related (Maximum Acceptable Concentration)
 AO: Ontario Drinking Water Standard - Non Health Related (Aesthetic Objective)
 mg/L: milligrams per litre, parts permillion (ppm)



Organics Test Results

Reading	Units	ODWS	22/01/2007	16/04/2007	09/07/2007	22/10/2007	01/11/2007
(DDT) + Metabolites	mg/L	0.03	MAC				< 0.000008
1,1-dichloroethylene (vinylidene chloride)	mg/L	0.014	MAC	< 0.0003	< 0.0003	< 0.0003	< 0.0003
1,2-(o-dcb) Dichlorobenzene	mg/L	0.2	MAC	< 0.0001	< 0.0001	< 0.0001	< 0.0001
1,2-Dichloroethane	mg/L	0.005	IMAC	< 0.0001	< 0.0001	< 0.0001	< 0.0001
1,4-(p-dcb) Dichlorobenzene	mg/L	0.005	MAC	< 0.0001	< 0.0001	< 0.0001	< 0.0001
2,3,4,6-Tetrachlorophenol	mg/L	0.1	MAC				< 0.0005
2,4,5-trichlorophenoxyacetic acid (2,4,5-T)	mg/L	0.28	MAC				< 0.0005
2,4,6-Trichlorophenol	mg/L	0.005	MAC				< 0.0005
2,4-Dichlorophenol	mg/L	0.9	MAC				< 0.0004
2,4-dichlorophenoxyacetic acid (2,4-D)	mg/L	0.1	IMAC				< 0.0008
Alachlor	mg/L	0.005	IMAC				< 0.0004
Aldicarb	mg/L	0.009	MAC				< 0.0035
Aldrin + Dieldrin	mg/L	0.0007	MAC				< 0.000006
Atrazine + N-dealkylated metabolites	mg/L	0.005	IMAC				< 0.0002
Azinphos-methyl	mg/L	0.02	MAC				< 0.0003
Bendiocarb	mg/L	0.04	MAC				< 0.003
Benzene	mg/L	0.005	MAC	< 0.0001	< 0.0001	< 0.0001	< 0.0001
Benzo(a)pyrene	mg/L	0.00001	MAC				< 0.00001
Bromoxynil	mg/L	0.005	IMAC				< 0.0004
Carbaryl	mg/L	0.09	MAC				< 0.0002
Carbofuran	mg/L	0.09	MAC				< 0.004
Carbon Tetrachloride	mg/L	0.005	MAC	< 0.0002	< 0.0002	< 0.0002	< 0.0002
Chlordane (Total)	mg/L	0.007	MAC				< 0.000006
Chlorpyrifos	mg/L	0.09	MAC				< 0.0002
Cyanazine	mg/L	0.01	IMAC				< 0.0003
Diazinon	mg/L	0.02	MAC				< 0.0002
Dicamba	mg/L	0.12	MAC				< 0.0004
Dichloromethane	mg/L	0.05	MAC	< 0.0005	< 0.001	< 0.0005	< 0.0005
Diclofop-methyl	mg/L	0.009	MAC				< 0.0004
Dimethoate	mg/L	0.02	IMAC				< 0.0003
Dinoseb	mg/L	0.01	MAC				< 0.0005
Diquat	mg/L	0.07	MAC				< 0.0001
Diuron	mg/L	0.15	MAC				< 0.0002
Glyphosate	mg/L	0.28	IMAC				< 0.002
Heptachlor + Heptachlor Epoxide	mg/L	0.003	MAC				< 0.000008
Lindane	mg/L	0.004	MAC				< 0.000005
Malathion	mg/L	0.19	MAC				< 0.0002
Methoxychlor	mg/L	0.9	MAC				< 0.000009
Metolachlor	mg/L	0.05	IMAC				< 0.0002
Metribuzin	mg/L	0.08	MAC				< 0.0003
Monochlorobenzene	mg/L	0.08	MAC	< 0.0001	< 0.0001	< 0.0001	< 0.0001
Paraquat	mg/L	0.01	IMAC				< 0.0001
Parathion	mg/L	0.05	MAC				< 0.0002



Organics Test Results

Reading	Units	ODWS		22/01/2007	16/04/2007	09/07/2007	22/10/2007	01/11/2007
Pentachlorophenol	mg/L	0.06	MAC				< 0.0004	
Phorate	mg/L	0.002	IMAC					< 0.0002
Picloram	mg/L	0.19	IMAC				< 0.0007	
Polychlorinated Biphenyls (PCBs)	mg/L	0.003	IMAC				< 0.00002	
Prometryne	mg/L	0.001	IMAC				< 0.0002	
Simazine	mg/L	0.01	IMAC				< 0.0002	
Temephos	mg/L	0.28	IMAC					< 0.003
Terbufos	mg/L	0.001	IMAC					< 0.0002
Tetrachloroethylene (perchloroethylene)	mg/L	0.03	MAC	< 0.0003	< 0.0003	< 0.0003	< 0.0003	
Triallate	mg/L	0.23	MAC				< 0.002	
Trichloroethene	mg/L	0.005	MAC	< 0.0001	< 0.0001	< 0.0001	< 0.0001	
Trifluralin	mg/L	0.045	IMAC				< 0.000006	
Vinyl Chloride	mg/L	0.002	MAC	< 0.0002	< 0.0002	< 0.0002	< 0.0002	

"<": indicates the result is below Method Detection Limit
 ODWS: Ontario Drinking Water Standard
 MAC: Ontario Drinking Water Standard - Health Related (Maximum Acceptable Concentration)
 AO: Ontario Drinking Water Standard - Non Health Related (Aesthetic Objective)
 mg/L: milligrams per litre, parts permillion (ppm)



Organics Test Results

Reading	Units	ODWS	22/01/2007	16/04/2007	09/07/2007	22/10/2007	31/10/2007
(DDT) + Metabolites	mg/L	0.03	MAC			< 0.000008	
1,1-dichloroethylene (vinylidene chloride)	mg/L	0.014	MAC	< 0.0003	< 0.0003	< 0.0003	< 0.0003
1,2-(o-dcb) Dichlorobenzene	mg/L	0.2	MAC	< 0.0001	< 0.0001	< 0.0001	< 0.0001
1,2-Dichloroethane	mg/L	0.005	IMAC	< 0.0001	< 0.0001	< 0.0001	< 0.0001
1,4-(p-dcb) Dichlorobenzene	mg/L	0.005	MAC	< 0.0001	< 0.0001	< 0.0001	< 0.0001
2,3,4,6-Tetrachlorophenol	mg/L	0.1	MAC			< 0.0005	
2,4,5-trichlorophenoxyacetic acid (2,4,5-T)	mg/L	0.28	MAC			< 0.0005	
2,4,6-Trichlorophenol	mg/L	0.005	MAC			< 0.0005	
2,4-Dichlorophenol	mg/L	0.9	MAC			< 0.0004	
2,4-dichlorophenoxyacetic acid (2,4-D)	mg/L	0.1	IMAC			< 0.0008	
Alachlor	mg/L	0.005	IMAC			< 0.0004	
Aldicarb	mg/L	0.009	MAC			< 0.0035	
Aldrin + Dieldrin	mg/L	0.0007	MAC			< 0.000006	
Atrazine + N-dealkylated metabolites	mg/L	0.005	IMAC			< 0.0002	
Azinphos-methyl	mg/L	0.02	MAC				< 0.0003
Bendiocarb	mg/L	0.04	MAC			< 0.003	
Benzene	mg/L	0.005	MAC	< 0.0001	< 0.0001	< 0.0001	< 0.0001
Benzo(a)pyrene	mg/L	0.00001	MAC			< 0.00001	
Bromoxynil	mg/L	0.005	IMAC			< 0.0004	
Carbaryl	mg/L	0.09	MAC			< 0.0002	
Carbofuran	mg/L	0.09	MAC			< 0.004	
Carbon Tetrachloride	mg/L	0.005	MAC	< 0.0002	< 0.0002	< 0.0002	< 0.0002
Chlordane (Total)	mg/L	0.007	MAC			< 0.000006	
Chlorpyrifos	mg/L	0.09	MAC				< 0.0002
Cyanazine	mg/L	0.01	IMAC			< 0.0003	
Diazinon	mg/L	0.02	MAC				< 0.0002
Dicamba	mg/L	0.12	MAC			< 0.0004	
Dichloromethane	mg/L	0.05	MAC	< 0.0005	< 0.001	< 0.0005	< 0.0005
Diclofop-methyl	mg/L	0.009	MAC			< 0.0004	
Dimethoate	mg/L	0.02	IMAC				< 0.0003
Dinoseb	mg/L	0.01	MAC			< 0.0005	
Diquat	mg/L	0.07	MAC			< 0.0001	
Diuron	mg/L	0.15	MAC			< 0.0002	
Glyphosate	mg/L	0.28	IMAC			< 0.002	
Heptachlor + Heptachlor Epoxide	mg/L	0.003	MAC			< 0.000008	
Lindane	mg/L	0.004	MAC			< 0.000005	
Malathion	mg/L	0.19	MAC				< 0.0002
Methoxychlor	mg/L	0.9	MAC			< 0.000009	
Metolachlor	mg/L	0.05	IMAC			< 0.0002	
Metribuzin	mg/L	0.08	MAC			< 0.0003	
Monochlorobenzene	mg/L	0.08	MAC	< 0.0001	< 0.0001	< 0.0001	< 0.0001
Paraquat	mg/L	0.01	IMAC			< 0.0001	
Parathion	mg/L	0.05	MAC				< 0.0002



Organics Test Results

Reading	Units	ODWS		22/01/2007	16/04/2007	09/07/2007	22/10/2007	31/10/2007
Pentachlorophenol	mg/L	0.06	MAC				< 0.0004	
Phorate	mg/L	0.002	IMAC					< 0.0002
Picloram	mg/L	0.19	IMAC				< 0.0007	
Polychlorinated Biphenyls (PCBs)	mg/L	0.003	IMAC				< 0.00002	
Prometryne	mg/L	0.001	IMAC				< 0.0002	
Simazine	mg/L	0.01	IMAC				< 0.0002	
Temephos	mg/L	0.28	IMAC					< 0.003
Terbufos	mg/L	0.001	IMAC					< 0.0002
Tetrachloroethylene (perchloroethylene)	mg/L	0.03	MAC	< 0.0003	< 0.0003	< 0.0003	< 0.0003	
Triallate	mg/L	0.23	MAC				< 0.002	
Trichloroethene	mg/L	0.005	MAC	< 0.0001	< 0.0001	< 0.0001	< 0.0001	
Trifluralin	mg/L	0.045	IMAC				< 0.000006	
Vinyl Chloride	mg/L	0.002	MAC	< 0.0002	< 0.0002	< 0.0002	< 0.0002	

"<": indicates the result is below Method Detection Limit
 ODWS: Ontario Drinking Water Standard
 MAC: Ontario Drinking Water Standard - Health Related (Maximum Acceptable Concentration)
 AO: Ontario Drinking Water Standard - Non Health Related (Aesthetic Objective)
 mg/L: milligrams per litre, parts permillion (ppm)



Organics Test Results

Reading	Units	ODWS		22/01/2007	16/04/2007	09/07/2007	22/10/2007
(DDT) + Metabolites	mg/L	0.03	MAC				< 0.000008
1,1-dichloroethylene (vinylidene chloride)	mg/L	0.014	MAC	< 0.0003	< 0.0003	< 0.0003	< 0.0003
1,2-(o-dcb) Dichlorobenzene	mg/L	0.2	MAC	< 0.0001	< 0.0001	< 0.0001	< 0.0001
1,2-Dichloroethane	mg/L	0.005	IMAC	< 0.0001	< 0.0001	< 0.0001	< 0.0001
1,4-(p-dcb) Dichlorobenzene	mg/L	0.005	MAC	< 0.0001	< 0.0001	< 0.0001	< 0.0001
2,3,4,6-Tetrachlorophenol	mg/L	0.1	MAC				< 0.0005
2,4,5-trichlorophenoxyacetic acid (2,4,5-T)	mg/L	0.28	MAC				< 0.0005
2,4,6-Trichlorophenol	mg/L	0.005	MAC				< 0.0005
2,4-Dichlorophenol	mg/L	0.9	MAC				< 0.0004
2,4-dichlorophenoxyacetic acid (2,4-D)	mg/L	0.1	IMAC				< 0.0008
Alachlor	mg/L	0.005	IMAC				< 0.0004
Aldicarb	mg/L	0.009	MAC				< 0.0035
Aldrin + Dieldrin	mg/L	0.0007	MAC				< 0.000006
Atrazine + N-dealkylated metabolites	mg/L	0.005	IMAC				< 0.0002
Azinphos-methyl	mg/L	0.02	MAC				< 0.0003
Bendiocarb	mg/L	0.04	MAC				< 0.003
Benzene	mg/L	0.005	MAC	< 0.0001	< 0.0001	< 0.0001	< 0.0001
Benzo(a)pyrene	mg/L	0.00001	MAC				< 0.00001
Bromoxynil	mg/L	0.005	IMAC				< 0.0004
Carbaryl	mg/L	0.09	MAC				< 0.0002
Carbofuran	mg/L	0.09	MAC				< 0.004
Carbon Tetrachloride	mg/L	0.005	MAC	< 0.0002	< 0.0002	< 0.0002	< 0.0002
Chlordane (Total)	mg/L	0.007	MAC				< 0.000006
Chlorpyrifos	mg/L	0.09	MAC				< 0.0002
Cyanazine	mg/L	0.01	IMAC				< 0.0003
Diazinon	mg/L	0.02	MAC				< 0.0002
Dicamba	mg/L	0.12	MAC				< 0.0004
Dichloromethane	mg/L	0.05	MAC	< 0.0005	< 0.001	< 0.0005	< 0.0005
Diclofop-methyl	mg/L	0.009	MAC				< 0.0004
Dimethoate	mg/L	0.02	IMAC				< 0.0003
Dinoseb	mg/L	0.01	MAC				< 0.0005
Diquat	mg/L	0.07	MAC				< 0.0001
Diuron	mg/L	0.15	MAC				< 0.0002
Glyphosate	mg/L	0.28	IMAC				< 0.002
Heptachlor + Heptachlor Epoxide	mg/L	0.003	MAC				< 0.000008
Lindane	mg/L	0.004	MAC				< 0.000005
Malathion	mg/L	0.19	MAC				< 0.0002
Methoxychlor	mg/L	0.9	MAC				< 0.000009
Metolachlor	mg/L	0.05	IMAC				< 0.0002
Metribuzin	mg/L	0.08	MAC				< 0.0003
Monochlorobenzene	mg/L	0.08	MAC	< 0.0001	< 0.0001	< 0.0001	< 0.0001
Paraquat	mg/L	0.01	IMAC				< 0.0001
Parathion	mg/L	0.05	MAC				< 0.0002



Organics Test Results

Reading	Units	ODWS		22/01/2007	16/04/2007	09/07/2007	22/10/2007
Pentachlorophenol	mg/L	0.06	MAC				< 0.0004
Phorate	mg/L	0.002	IMAC				< 0.0002
Picloram	mg/L	0.19	IMAC				< 0.0007
Polychlorinated Biphenyls (PCBs)	mg/L	0.003	IMAC				< 0.00002
Prometryne	mg/L	0.001	IMAC				< 0.0002
Simazine	mg/L	0.01	IMAC				< 0.0002
Temephos	mg/L	0.28	IMAC				< 0.003
Terbufos	mg/L	0.001	IMAC				< 0.0002
Tetrachloroethylene (perchloroethylene)	mg/L	0.03	MAC	< 0.0003	< 0.0003	< 0.0003	< 0.0003
Triallate	mg/L	0.23	MAC				< 0.002
Trichloroethene	mg/L	0.005	MAC	< 0.0001	< 0.0001	< 0.0001	< 0.0001
Trifluralin	mg/L	0.045	IMAC				< 0.000006
Vinyl Chloride	mg/L	0.002	MAC	< 0.0002	< 0.0002	< 0.0002	< 0.0002

"<": indicates the result is below Method Detection Limit

ODWS: Ontario Drinking Water Standard

MAC: Ontario Drinking Water Standard - Health Related (Maximum Acceptable Concentration)

AO: Ontario Drinking Water Standard - Non Health Related (Aesthetic Objective)

mg/L: milligrams per litre, parts permillion (ppm)



Organics Test Results

Reading	Units	ODWS	22/01/2007	16/04/2007	09/07/2007	22/10/2007	01/11/2007
(DDT) + Metabolites	mg/L	0.03	MAC				< 0.000008
1,1-dichloroethylene (vinylidene chloride)	mg/L	0.014	MAC	< 0.0003	< 0.0003	< 0.0003	< 0.0003
1,2-(o-dcb) Dichlorobenzene	mg/L	0.2	MAC	< 0.0001	< 0.0001	< 0.0001	< 0.0001
1,2-Dichloroethane	mg/L	0.005	IMAC	< 0.0001	< 0.0001	< 0.0001	< 0.0001
1,4-(p-dcb) Dichlorobenzene	mg/L	0.005	MAC	< 0.0001	< 0.0001	< 0.0001	< 0.0001
2,3,4,6-Tetrachlorophenol	mg/L	0.1	MAC				< 0.0005
2,4,5-trichlorophenoxyacetic acid (2,4,5-T)	mg/L	0.28	MAC				< 0.0005
2,4,6-Trichlorophenol	mg/L	0.005	MAC				< 0.0005
2,4-Dichlorophenol	mg/L	0.9	MAC				< 0.0004
2,4-dichlorophenoxyacetic acid (2,4-D)	mg/L	0.1	IMAC				< 0.0008
Alachlor	mg/L	0.005	IMAC				< 0.0004
Aldicarb	mg/L	0.009	MAC				< 0.0035
Aldrin + Dieldrin	mg/L	0.0007	MAC				< 0.000006
Atrazine + N-dealkylated metabolites	mg/L	0.005	IMAC				< 0.0002
Azinphos-methyl	mg/L	0.02	MAC				< 0.0003
Bendiocarb	mg/L	0.04	MAC				< 0.003
Benzene	mg/L	0.005	MAC	< 0.0001	< 0.0001	< 0.0001	< 0.0001
Benzo(a)pyrene	mg/L	0.00001	MAC				< 0.00001
Bromoxynil	mg/L	0.005	IMAC				< 0.0004
Carbaryl	mg/L	0.09	MAC				< 0.0002
Carbofuran	mg/L	0.09	MAC				< 0.004
Carbon Tetrachloride	mg/L	0.005	MAC	< 0.0002	< 0.0002	< 0.0002	< 0.0002
Chlordane (Total)	mg/L	0.007	MAC				< 0.000006
Chlorpyrifos	mg/L	0.09	MAC				< 0.0002
Cyanazine	mg/L	0.01	IMAC				< 0.0003
Diazinon	mg/L	0.02	MAC				< 0.0002
Dicamba	mg/L	0.12	MAC				< 0.0004
Dichloromethane	mg/L	0.05	MAC	< 0.0005	< 0.001	< 0.0005	< 0.0005
Diclofop-methyl	mg/L	0.009	MAC				< 0.0004
Dimethoate	mg/L	0.02	IMAC				< 0.0003
Dinoseb	mg/L	0.01	MAC				< 0.0005
Diquat	mg/L	0.07	MAC				< 0.0001
Diuron	mg/L	0.15	MAC				< 0.0002
Glyphosate	mg/L	0.28	IMAC				< 0.002
Heptachlor + Heptachlor Epoxide	mg/L	0.003	MAC				< 0.000008
Lindane	mg/L	0.004	MAC				< 0.000005
Malathion	mg/L	0.19	MAC				< 0.0002
Methoxychlor	mg/L	0.9	MAC				< 0.000009
Metolachlor	mg/L	0.05	IMAC				< 0.0002
Metribuzin	mg/L	0.08	MAC				< 0.0003
Monochlorobenzene	mg/L	0.08	MAC	< 0.0001	< 0.0001	< 0.0001	< 0.0001
Paraquat	mg/L	0.01	IMAC				< 0.0001
Parathion	mg/L	0.05	MAC				< 0.0002



Organics Test Results

Reading	Units	ODWS		22/01/2007	16/04/2007	09/07/2007	22/10/2007	01/11/2007
Pentachlorophenol	mg/L	0.06	MAC				< 0.0004	
Phorate	mg/L	0.002	IMAC					< 0.0002
Picloram	mg/L	0.19	IMAC				< 0.0007	
Polychlorinated Biphenyls (PCBs)	mg/L	0.003	IMAC				< 0.00002	
Prometryne	mg/L	0.001	IMAC				< 0.0002	
Simazine	mg/L	0.01	IMAC				< 0.0002	
Temephos	mg/L	0.28	IMAC					< 0.003
Terbufos	mg/L	0.001	IMAC					< 0.0002
Tetrachloroethylene (perchloroethylene)	mg/L	0.03	MAC	< 0.0003	< 0.0003	< 0.0003	< 0.0003	
Triallate	mg/L	0.23	MAC				< 0.002	
Trichloroethene	mg/L	0.005	MAC	< 0.0001	< 0.0001	< 0.0001	< 0.0001	
Trifluralin	mg/L	0.045	IMAC				< 0.000006	
Vinyl Chloride	mg/L	0.002	MAC	< 0.0002	< 0.0002	< 0.0002	< 0.0002	

"<": indicates the result is below Method Detection Limit
 ODWS: Ontario Drinking Water Standard
 MAC: Ontario Drinking Water Standard - Health Related (Maximum Acceptable Concentration)
 AO: Ontario Drinking Water Standard - Non Health Related (Aesthetic Objective)
 mg/L: milligrams per litre, parts permillion (ppm)



Organics Test Results

Reading	Units	ODWS	22/01/2007	16/04/2007	09/07/2007	22/10/2007	01/11/2007
(DDT) + Metabolites	mg/L	0.03	MAC			< 0.000008	
1,1-dichloroethylene (vinylidene chloride)	mg/L	0.014	MAC	< 0.0003	< 0.0003	< 0.0003	< 0.0003
1,2-(o-dcb) Dichlorobenzene	mg/L	0.2	MAC	< 0.0001	< 0.0001	< 0.0001	< 0.0001
1,2-Dichloroethane	mg/L	0.005	IMAC	< 0.0001	< 0.0001	< 0.0001	< 0.0001
1,4-(p-dcb) Dichlorobenzene	mg/L	0.005	MAC	< 0.0001	< 0.0001	< 0.0001	< 0.0001
2,3,4,6-Tetrachlorophenol	mg/L	0.1	MAC			< 0.0005	
2,4,5-trichlorophenoxyacetic acid (2,4,5-T)	mg/L	0.28	MAC			< 0.0005	
2,4,6-Trichlorophenol	mg/L	0.005	MAC			< 0.0005	
2,4-Dichlorophenol	mg/L	0.9	MAC			< 0.0004	
2,4-dichlorophenoxyacetic acid (2,4-D)	mg/L	0.1	IMAC			< 0.0008	
Alachlor	mg/L	0.005	IMAC			< 0.0004	
Aldicarb	mg/L	0.009	MAC			< 0.0035	
Aldrin + Dieldrin	mg/L	0.0007	MAC			< 0.000006	
Atrazine + N-dealkylated metabolites	mg/L	0.005	IMAC			< 0.0002	
Azinphos-methyl	mg/L	0.02	MAC				< 0.0003
Bendiocarb	mg/L	0.04	MAC			< 0.003	
Benzene	mg/L	0.005	MAC	< 0.0001	< 0.0001	< 0.0001	< 0.0001
Benzo(a)pyrene	mg/L	0.00001	MAC			< 0.00001	
Bromoxynil	mg/L	0.005	IMAC			< 0.0004	
Carbaryl	mg/L	0.09	MAC			< 0.0002	
Carbofuran	mg/L	0.09	MAC			< 0.004	
Carbon Tetrachloride	mg/L	0.005	MAC	< 0.0002	< 0.0002	< 0.0002	< 0.0002
Chlordane (Total)	mg/L	0.007	MAC			< 0.000006	
Chlorpyrifos	mg/L	0.09	MAC				< 0.0002
Cyanazine	mg/L	0.01	IMAC			< 0.0003	
Diazinon	mg/L	0.02	MAC				< 0.0002
Dicamba	mg/L	0.12	MAC			< 0.0004	
Dichloromethane	mg/L	0.05	MAC	< 0.0005	< 0.001	< 0.0005	< 0.0005
Diclofop-methyl	mg/L	0.009	MAC			< 0.0004	
Dimethoate	mg/L	0.02	IMAC				< 0.0003
Dinoseb	mg/L	0.01	MAC			< 0.0005	
Diquat	mg/L	0.07	MAC			< 0.0001	
Diuron	mg/L	0.15	MAC			< 0.0002	
Glyphosate	mg/L	0.28	IMAC			< 0.002	
Heptachlor + Heptachlor Epoxide	mg/L	0.003	MAC			< 0.000008	
Lindane	mg/L	0.004	MAC			< 0.000005	
Malathion	mg/L	0.19	MAC				< 0.0002
Methoxychlor	mg/L	0.9	MAC			< 0.000009	
Metolachlor	mg/L	0.05	IMAC			< 0.0002	
Metribuzin	mg/L	0.08	MAC			< 0.0003	
Monochlorobenzene	mg/L	0.08	MAC	< 0.0001	< 0.0001	< 0.0001	< 0.0001
Paraquat	mg/L	0.01	IMAC			< 0.0001	
Parathion	mg/L	0.05	MAC				< 0.0002



Organics Test Results

Reading	Units	ODWS		22/01/2007	16/04/2007	09/07/2007	22/10/2007	01/11/2007
Pentachlorophenol	mg/L	0.06	MAC				< 0.0004	
Phorate	mg/L	0.002	IMAC					< 0.0002
Picloram	mg/L	0.19	IMAC				< 0.0007	
Polychlorinated Biphenyls (PCBs)	mg/L	0.003	IMAC				< 0.00002	
Prometryne	mg/L	0.001	IMAC				< 0.0002	
Simazine	mg/L	0.01	IMAC				< 0.0002	
Temephos	mg/L	0.28	IMAC					< 0.003
Terbufos	mg/L	0.001	IMAC					< 0.0002
Tetrachloroethylene (perchloroethylene)	mg/L	0.03	MAC	< 0.0003	< 0.0003	< 0.0003	< 0.0003	
Triallate	mg/L	0.23	MAC				< 0.002	
Trichloroethene	mg/L	0.005	MAC	< 0.0001	< 0.0001	< 0.0001	< 0.0001	
Trifluralin	mg/L	0.045	IMAC				< 0.000006	
Vinyl Chloride	mg/L	0.002	MAC	< 0.0002	< 0.0002	< 0.0002	< 0.0002	

"<": indicates the result is below Method Detection Limit

ODWS: Ontario Drinking Water Standard

MAC: Ontario Drinking Water Standard - Health Related (Maximum Acceptable Concentration)

AO: Ontario Drinking Water Standard - Non Health Related (Aesthetic Objective)

mg/L: milligrams per litre, parts permillion (ppm)



Organics Test Results

Reading	Units	ODWS	22/01/2007	16/04/2007	09/07/2007	22/10/2007	01/11/2007
(DDT) + Metabolites	mg/L	0.03	MAC				< 0.000008
1,1-dichloroethylene (vinylidene chloride)	mg/L	0.014	MAC	< 0.0003	< 0.0003	< 0.0003	< 0.0003
1,2-(o-dcb) Dichlorobenzene	mg/L	0.2	MAC	< 0.0001	< 0.0001	< 0.0001	< 0.0001
1,2-Dichloroethane	mg/L	0.005	IMAC	< 0.0001	< 0.0001	< 0.0001	< 0.0001
1,4-(p-dcb) Dichlorobenzene	mg/L	0.005	MAC	< 0.0001	< 0.0001	< 0.0001	< 0.0001
2,3,4,6-Tetrachlorophenol	mg/L	0.1	MAC				< 0.0005
2,4,5-trichlorophenoxyacetic acid (2,4,5-T)	mg/L	0.28	MAC				< 0.0005
2,4,6-Trichlorophenol	mg/L	0.005	MAC				< 0.0005
2,4-Dichlorophenol	mg/L	0.9	MAC				< 0.0004
2,4-dichlorophenoxyacetic acid (2,4-D)	mg/L	0.1	IMAC				< 0.0008
Alachlor	mg/L	0.005	IMAC				< 0.0004
Aldicarb	mg/L	0.009	MAC				< 0.0035
Aldrin + Dieldrin	mg/L	0.0007	MAC				< 0.000006
Atrazine + N-dealkylated metabolites	mg/L	0.005	IMAC				< 0.0002
Azinphos-methyl	mg/L	0.02	MAC				< 0.0003
Bendiocarb	mg/L	0.04	MAC				< 0.003
Benzene	mg/L	0.005	MAC	< 0.0001	< 0.0001	< 0.0001	< 0.0001
Benzo(a)pyrene	mg/L	0.00001	MAC				< 0.00001
Bromoxynil	mg/L	0.005	IMAC				< 0.0004
Carbaryl	mg/L	0.09	MAC				< 0.0002
Carbofuran	mg/L	0.09	MAC				< 0.004
Carbon Tetrachloride	mg/L	0.005	MAC	< 0.0002	< 0.0002	< 0.0002	< 0.0002
Chlordane (Total)	mg/L	0.007	MAC				< 0.000006
Chlorpyrifos	mg/L	0.09	MAC				< 0.0002
Cyanazine	mg/L	0.01	IMAC				< 0.0003
Diazinon	mg/L	0.02	MAC				< 0.0002
Dicamba	mg/L	0.12	MAC				< 0.0004
Dichloromethane	mg/L	0.05	MAC	< 0.0005	< 0.001	< 0.0005	< 0.0005
Diclofop-methyl	mg/L	0.009	MAC				< 0.0004
Dimethoate	mg/L	0.02	IMAC				< 0.0003
Dinoseb	mg/L	0.01	MAC				< 0.0005
Diquat	mg/L	0.07	MAC				< 0.0001
Diuron	mg/L	0.15	MAC				< 0.0002
Glyphosate	mg/L	0.28	IMAC				< 0.002
Heptachlor + Heptachlor Epoxide	mg/L	0.003	MAC				< 0.000008
Lindane	mg/L	0.004	MAC				< 0.000005
Malathion	mg/L	0.19	MAC				< 0.0002
Methoxychlor	mg/L	0.9	MAC				< 0.000009
Metolachlor	mg/L	0.05	IMAC				< 0.0002
Metribuzin	mg/L	0.08	MAC				< 0.0003
Monochlorobenzene	mg/L	0.08	MAC	< 0.0001	< 0.0001	< 0.0001	< 0.0001
Paraquat	mg/L	0.01	IMAC				< 0.0001
Parathion	mg/L	0.05	MAC				< 0.0002



Organics Test Results

Reading	Units	ODWS		22/01/2007	16/04/2007	09/07/2007	22/10/2007	01/11/2007
Pentachlorophenol	mg/L	0.06	MAC				< 0.0004	
Phorate	mg/L	0.002	IMAC					< 0.0002
Picloram	mg/L	0.19	IMAC				< 0.0007	
Polychlorinated Biphenyls (PCBs)	mg/L	0.003	IMAC				< 0.00002	
Prometryne	mg/L	0.001	IMAC				< 0.0002	
Simazine	mg/L	0.01	IMAC				< 0.0002	
Temephos	mg/L	0.28	IMAC					< 0.003
Terbufos	mg/L	0.001	IMAC					< 0.0002
Tetrachloroethylene (perchloroethylene)	mg/L	0.03	MAC	< 0.0003	< 0.0003	< 0.0003	< 0.0003	
Triallate	mg/L	0.23	MAC				< 0.002	
Trichloroethene	mg/L	0.005	MAC	< 0.0001	< 0.0001	< 0.0001	< 0.0001	
Trifluralin	mg/L	0.045	IMAC				< 0.000006	
Vinyl Chloride	mg/L	0.002	MAC	< 0.0002	< 0.0002	< 0.0002	< 0.0002	

"<": indicates the result is below Method Detection Limit
 ODWS: Ontario Drinking Water Standard
 MAC: Ontario Drinking Water Standard - Health Related (Maximum Acceptable Concentration)
 AO: Ontario Drinking Water Standard - Non Health Related (Aesthetic Objective)
 mg/L: milligrams per litre, parts permillion (ppm)



Organics Test Results

Reading	Units	ODWS	22/01/2007	16/04/2007	09/07/2007	22/10/2007
(DDT) + Metabolites	mg/L	0.03	MAC			< 0.000008
1,1-dichloroethylene (vinylidene chloride)	mg/L	0.014	MAC	< 0.0003	< 0.0003	< 0.0003
1,2-(o-dcb) Dichlorobenzene	mg/L	0.2	MAC	< 0.0001	< 0.0001	< 0.0001
1,2-Dichloroethane	mg/L	0.005	IMAC	< 0.0001	< 0.0001	< 0.0001
1,4-(p-dcb) Dichlorobenzene	mg/L	0.005	MAC	< 0.0001	< 0.0001	< 0.0001
2,3,4,6-Tetrachlorophenol	mg/L	0.1	MAC			< 0.0005
2,4,5-trichlorophenoxyacetic acid (2,4,5-T)	mg/L	0.28	MAC			< 0.0005
2,4,6-Trichlorophenol	mg/L	0.005	MAC			< 0.0005
2,4-Dichlorophenol	mg/L	0.9	MAC			< 0.0004
2,4-dichlorophenoxyacetic acid (2,4-D)	mg/L	0.1	IMAC			< 0.0008
Alachlor	mg/L	0.005	IMAC			< 0.0004
Aldicarb	mg/L	0.009	MAC			< 0.0035
Aldrin + Dieldrin	mg/L	0.0007	MAC			< 0.000006
Atrazine + N-dealkylated metabolites	mg/L	0.005	IMAC			< 0.0002
Azinphos-methyl	mg/L	0.02	MAC			< 0.0003
Bendiocarb	mg/L	0.04	MAC			< 0.003
Benzene	mg/L	0.005	MAC	< 0.0001	< 0.0001	< 0.0001
Benzo(a)pyrene	mg/L	0.00001	MAC			< 0.00001
Bromoxynil	mg/L	0.005	IMAC			< 0.0004
Carbaryl	mg/L	0.09	MAC			< 0.0002
Carbofuran	mg/L	0.09	MAC			< 0.004
Carbon Tetrachloride	mg/L	0.005	MAC	< 0.0002	< 0.0002	< 0.0002
Chlordane (Total)	mg/L	0.007	MAC			< 0.000006
Chlorpyrifos	mg/L	0.09	MAC			< 0.0002
Cyanazine	mg/L	0.01	IMAC			< 0.0003
Diazinon	mg/L	0.02	MAC			< 0.0002
Dicamba	mg/L	0.12	MAC			< 0.0004
Dichloromethane	mg/L	0.05	MAC	< 0.0005	< 0.001	< 0.0005
Diclofop-methyl	mg/L	0.009	MAC			< 0.0004
Dimethoate	mg/L	0.02	IMAC			< 0.0003
Dinoseb	mg/L	0.01	MAC			< 0.0005
Diquat	mg/L	0.07	MAC			< 0.0001
Diuron	mg/L	0.15	MAC			< 0.0002
Glyphosate	mg/L	0.28	IMAC			< 0.002
Heptachlor + Heptachlor Epoxide	mg/L	0.003	MAC			< 0.000008
Lindane	mg/L	0.004	MAC			< 0.000005
Malathion	mg/L	0.19	MAC			< 0.0002
Methoxychlor	mg/L	0.9	MAC			< 0.000009
Metolachlor	mg/L	0.05	IMAC			< 0.0002
Metribuzin	mg/L	0.08	MAC			< 0.0003
Monochlorobenzene	mg/L	0.08	MAC	< 0.0001	< 0.0001	< 0.0001
Paraquat	mg/L	0.01	IMAC			< 0.0001
Parathion	mg/L	0.05	MAC			< 0.0002



Organics Test Results

Reading	Units	ODWS		22/01/2007	16/04/2007	09/07/2007	22/10/2007
Pentachlorophenol	mg/L	0.06	MAC				< 0.0004
Phorate	mg/L	0.002	IMAC				< 0.0002
Picloram	mg/L	0.19	IMAC				< 0.0007
Polychlorinated Biphenyls (PCBs)	mg/L	0.003	IMAC				< 0.00002
Prometryne	mg/L	0.001	IMAC				< 0.0002
Simazine	mg/L	0.01	IMAC				< 0.0002
Temephos	mg/L	0.28	IMAC				< 0.003
Terbufos	mg/L	0.001	IMAC				< 0.0002
Tetrachloroethylene (perchloroethylene)	mg/L	0.03	MAC	< 0.0003	< 0.0003	< 0.0003	< 0.0003
Triallate	mg/L	0.23	MAC				< 0.002
Trichloroethene	mg/L	0.005	MAC	< 0.0001	< 0.0001	< 0.0001	< 0.0001
Trifluralin	mg/L	0.045	IMAC				< 0.000006
Vinyl Chloride	mg/L	0.002	MAC	< 0.0002	< 0.0002	< 0.0002	< 0.0002

"<": indicates the result is below Method Detection Limit
 ODWS: Ontario Drinking Water Standard
 MAC: Ontario Drinking Water Standard - Health Related (Maximum Acceptable Concentration)
 AO: Ontario Drinking Water Standard - Non Health Related (Aesthetic Objective)
 mg/L: milligrams per litre, parts permillion (ppm)



Organics Test Results

Reading	Units	ODWS	22/01/2007	16/04/2007	09/07/2007	22/10/2007
(DDT) + Metabolites	mg/L	0.03	MAC			< 0.000008
1,1-dichloroethylene (vinylidene chloride)	mg/L	0.014	MAC	< 0.0003	< 0.0003	< 0.0003
1,2-(o-dcb) Dichlorobenzene	mg/L	0.2	MAC	< 0.0001	< 0.0001	< 0.0001
1,2-Dichloroethane	mg/L	0.005	IMAC	< 0.0001	< 0.0001	< 0.0001
1,4-(p-dcb) Dichlorobenzene	mg/L	0.005	MAC	< 0.0001	< 0.0001	< 0.0001
2,3,4,6-Tetrachlorophenol	mg/L	0.1	MAC			< 0.0005
2,4,5-trichlorophenoxyacetic acid (2,4,5-T)	mg/L	0.28	MAC			< 0.0005
2,4,6-Trichlorophenol	mg/L	0.005	MAC			< 0.0005
2,4-Dichlorophenol	mg/L	0.9	MAC			< 0.0004
2,4-dichlorophenoxyacetic acid (2,4-D)	mg/L	0.1	IMAC			< 0.0008
Alachlor	mg/L	0.005	IMAC			< 0.0004
Aldicarb	mg/L	0.009	MAC			< 0.0035
Aldrin + Dieldrin	mg/L	0.0007	MAC			< 0.000006
Atrazine + N-dealkylated metabolites	mg/L	0.005	IMAC			< 0.0002
Azinphos-methyl	mg/L	0.02	MAC			< 0.0003
Bendiocarb	mg/L	0.04	MAC			< 0.003
Benzene	mg/L	0.005	MAC	< 0.0001	< 0.0001	< 0.0001
Benzo(a)pyrene	mg/L	0.00001	MAC			< 0.00001
Bromoxynil	mg/L	0.005	IMAC			< 0.0004
Carbaryl	mg/L	0.09	MAC			< 0.0002
Carbofuran	mg/L	0.09	MAC			< 0.004
Carbon Tetrachloride	mg/L	0.005	MAC	< 0.0002	< 0.0002	< 0.0002
Chlordane (Total)	mg/L	0.007	MAC			< 0.000006
Chlorpyrifos	mg/L	0.09	MAC			< 0.0002
Cyanazine	mg/L	0.01	IMAC			< 0.0003
Diazinon	mg/L	0.02	MAC			< 0.0002
Dicamba	mg/L	0.12	MAC			< 0.0004
Dichloromethane	mg/L	0.05	MAC	< 0.0005	< 0.001	< 0.0005
Diclofop-methyl	mg/L	0.009	MAC			< 0.0004
Dimethoate	mg/L	0.02	IMAC			< 0.0003
Dinoseb	mg/L	0.01	MAC			< 0.0005
Diquat	mg/L	0.07	MAC			< 0.0001
Diuron	mg/L	0.15	MAC			< 0.0002
Glyphosate	mg/L	0.28	IMAC			< 0.002
Heptachlor + Heptachlor Epoxide	mg/L	0.003	MAC			< 0.000008
Lindane	mg/L	0.004	MAC			< 0.000005
Malathion	mg/L	0.19	MAC			< 0.0002
Methoxychlor	mg/L	0.9	MAC			< 0.000009
Metolachlor	mg/L	0.05	IMAC			< 0.0002
Metribuzin	mg/L	0.08	MAC			< 0.0003
Monochlorobenzene	mg/L	0.08	MAC	< 0.0001	< 0.0001	< 0.0001
Paraquat	mg/L	0.01	IMAC			< 0.0001
Parathion	mg/L	0.05	MAC			< 0.0002



Organics Test Results

Reading	Units	ODWS		22/01/2007	16/04/2007	09/07/2007	22/10/2007
Pentachlorophenol	mg/L	0.06	MAC				< 0.0004
Phorate	mg/L	0.002	IMAC				< 0.0002
Picloram	mg/L	0.19	IMAC				< 0.0007
Polychlorinated Biphenyls (PCBs)	mg/L	0.003	IMAC				< 0.00002
Prometryne	mg/L	0.001	IMAC				< 0.0002
Simazine	mg/L	0.01	IMAC				< 0.0002
Temephos	mg/L	0.28	IMAC				< 0.003
Terbufos	mg/L	0.001	IMAC				< 0.0002
Tetrachloroethylene (perchloroethylene)	mg/L	0.03	MAC	< 0.0003	< 0.0003	< 0.0003	< 0.0003
Triallate	mg/L	0.23	MAC				< 0.002
Trichloroethene	mg/L	0.005	MAC	< 0.0001	< 0.0001	< 0.0001	< 0.0001
Trifluralin	mg/L	0.045	IMAC				< 0.000006
Vinyl Chloride	mg/L	0.002	MAC	< 0.0002	< 0.0002	< 0.0002	< 0.0002

"<": indicates the result is below Method Detection Limit
ODWS: Ontario Drinking Water Standard
MAC: Ontario Drinking Water Standard - Health Related (Maximum Acceptable Concentration)
AO: Ontario Drinking Water Standard - Non Health Related (Aesthetic Objective)
mg/L: milligrams per litre, parts permillion (ppm)



Organics Test Results

Reading	Units	ODWS		01/01/2007	25/04/2007	26/07/2007	17/10/2007
1,1-dichloroethylene (vinylidene chloride)	mg/L	0.014	MAC	< 0.0003	< 0.0003	< 0.0003	< 0.0003
1,2-(o-dcb) Dichlorobenzene	mg/L	0.2	MAC	< 0.0001	< 0.0001	< 0.0001	< 0.0001
1,2-Dichloroethane	mg/L	0.005	IMAC	< 0.0001	< 0.0001	< 0.0001	< 0.0001
1,4-(p-dcb) Dichlorobenzene	mg/L	0.005	MAC	< 0.0001	< 0.0001	< 0.0001	< 0.0001
Benzene	mg/L	0.005	MAC	< 0.0001	< 0.0001	< 0.0001	< 0.0001
Carbon Tetrachloride	mg/L	0.005	MAC	< 0.0002	< 0.0002	< 0.0002	< 0.0002
Dichloromethane	mg/L	0.05	MAC	< 0.0005	< 0.001	< 0.0005	< 0.0005
Monochlorobenzene	mg/L	0.08	MAC	< 0.0001	< 0.0001	< 0.0001	< 0.0001
Tetrachloroethylene (perchloroethylene)	mg/L	0.03	MAC	< 0.0003	< 0.0003	< 0.0003	< 0.0003
Trichloroethene	mg/L	0.005	MAC	< 0.0001	< 0.0001	< 0.0001	< 0.0001
Vinyl Chloride	mg/L	0.002	MAC	< 0.0002	< 0.0002	< 0.0002	< 0.0002

"<": indicates the result is below Method Detection Limit
ODWS: Ontario Drinking Water Standard
MAC: Ontario Drinking Water Standard - Health Related (Maximum Acceptable Concentration)
AO: Ontario Drinking Water Standard - Non Health Related (Aesthetic Objective)
mg/L: milligrams per litre, parts permillion (ppm)



Organics Test Results

Reading	Units	ODWS		22/01/2007	16/04/2007	09/07/2007	22/10/2007
(DDT) + Metabolites	mg/L	0.03	MAC				< 0.000008
1,1-dichloroethylene (vinylidene chloride)	mg/L	0.014	MAC	< 0.0003	< 0.0003	< 0.0003	< 0.0003
1,2-(o-dcb) Dichlorobenzene	mg/L	0.2	MAC	< 0.0001	< 0.0001	< 0.0001	< 0.0001
1,2-Dichloroethane	mg/L	0.005	IMAC	< 0.0001	< 0.0001	< 0.0001	< 0.0001
1,4-(p-dcb) Dichlorobenzene	mg/L	0.005	MAC	< 0.0001	< 0.0001	< 0.0001	< 0.0001
2,3,4,6-Tetrachlorophenol	mg/L	0.1	MAC				< 0.0005
2,4,5-trichlorophenoxyacetic acid (2,4,5-T)	mg/L	0.28	MAC				< 0.0005
2,4,6-Trichlorophenol	mg/L	0.005	MAC				< 0.0005
2,4-Dichlorophenol	mg/L	0.9	MAC				< 0.0004
2,4-dichlorophenoxyacetic acid (2,4-D)	mg/L	0.1	IMAC				< 0.0008
Alachlor	mg/L	0.005	IMAC				< 0.0004
Aldicarb	mg/L	0.009	MAC				< 0.0035
Aldrin + Dieldrin	mg/L	0.0007	MAC				< 0.000006
Atrazine + N-dealkylated metabolites	mg/L	0.005	IMAC				< 0.0002
Azinphos-methyl	mg/L	0.02	MAC				< 0.0003
Bendiocarb	mg/L	0.04	MAC				< 0.003
Benzene	mg/L	0.005	MAC	< 0.0001	< 0.0001	< 0.0001	< 0.0001
Benzo(a)pyrene	mg/L	0.00001	MAC				< 0.00001
Bromoxynil	mg/L	0.005	IMAC				< 0.0004
Carbaryl	mg/L	0.09	MAC				< 0.0002
Carbofuran	mg/L	0.09	MAC				< 0.004
Carbon Tetrachloride	mg/L	0.005	MAC	< 0.0002	< 0.0002	< 0.0002	< 0.0002
Chlordane (Total)	mg/L	0.007	MAC				< 0.000006
Chlorpyrifos	mg/L	0.09	MAC				< 0.0002
Cyanazine	mg/L	0.01	IMAC				< 0.0003
Diazinon	mg/L	0.02	MAC				< 0.0002
Dicamba	mg/L	0.12	MAC				< 0.0004
Dichloromethane	mg/L	0.05	MAC	< 0.0005	< 0.001	< 0.0005	< 0.0005
Diclofop-methyl	mg/L	0.009	MAC				< 0.0004
Dimethoate	mg/L	0.02	IMAC				< 0.0003
Dinoseb	mg/L	0.01	MAC				< 0.0005
Diquat	mg/L	0.07	MAC				< 0.0001
Diuron	mg/L	0.15	MAC				< 0.0002
Glyphosate	mg/L	0.28	IMAC				< 0.002
Heptachlor + Heptachlor Epoxide	mg/L	0.003	MAC				< 0.000008
Lindane	mg/L	0.004	MAC				< 0.000005
Malathion	mg/L	0.19	MAC				< 0.0002
Methoxychlor	mg/L	0.9	MAC				< 0.000009
Metolachlor	mg/L	0.05	IMAC				< 0.0002
Metribuzin	mg/L	0.08	MAC				< 0.0003
Monochlorobenzene	mg/L	0.08	MAC	< 0.0001	< 0.0001	< 0.0001	< 0.0001
Paraquat	mg/L	0.01	IMAC				< 0.0001
Parathion	mg/L	0.05	MAC				< 0.0002



Organics Test Results

Reading	Units	ODWS		22/01/2007	16/04/2007	09/07/2007	22/10/2007
Pentachlorophenol	mg/L	0.06	MAC				< 0.0004
Phorate	mg/L	0.002	IMAC				< 0.0002
Picloram	mg/L	0.19	IMAC				< 0.0007
Polychlorinated Biphenyls (PCBs)	mg/L	0.003	IMAC				< 0.00002
Prometryne	mg/L	0.001	IMAC				< 0.0002
Simazine	mg/L	0.01	IMAC				< 0.0002
Temephos	mg/L	0.28	IMAC				< 0.003
Terbufos	mg/L	0.001	IMAC				< 0.0002
Tetrachloroethylene (perchloroethylene)	mg/L	0.03	MAC	< 0.0003	< 0.0003	< 0.0003	< 0.0003
Triallate	mg/L	0.23	MAC				< 0.002
Trichloroethene	mg/L	0.005	MAC	< 0.0001	< 0.0001	< 0.0001	< 0.0001
Trifluralin	mg/L	0.045	IMAC				< 0.000006
Vinyl Chloride	mg/L	0.002	MAC	< 0.0002	< 0.0002	< 0.0002	< 0.0002

"<": indicates the result is below Method Detection Limit

ODWS: Ontario Drinking Water Standard

MAC: Ontario Drinking Water Standard - Health Related (Maximum Acceptable Concentration)

AO: Ontario Drinking Water Standard - Non Health Related (Aesthetic Objective)

mg/L: milligrams per litre, parts permillion (ppm)



Organics Test Results

Reading	Units	ODWS		22/01/2007	16/04/2007	09/07/2007	22/10/2007
(DDT) + Metabolites	mg/L	0.03	MAC				< 0.000008
1,1-dichloroethylene (vinylidene chloride)	mg/L	0.014	MAC	< 0.0003	< 0.0003	< 0.0003	< 0.0003
1,2-(o-dcb) Dichlorobenzene	mg/L	0.2	MAC	< 0.0001	< 0.0001	< 0.0001	< 0.0001
1,2-Dichloroethane	mg/L	0.005	IMAC	< 0.0001	< 0.0001	< 0.0001	< 0.0001
1,4-(p-dcb) Dichlorobenzene	mg/L	0.005	MAC	< 0.0001	< 0.0001	< 0.0001	< 0.0001
2,3,4,6-Tetrachlorophenol	mg/L	0.1	MAC				< 0.0005
2,4,5-trichlorophenoxyacetic acid (2,4,5-T)	mg/L	0.28	MAC				< 0.0005
2,4,6-Trichlorophenol	mg/L	0.005	MAC				< 0.0005
2,4-Dichlorophenol	mg/L	0.9	MAC				< 0.0004
2,4-dichlorophenoxyacetic acid (2,4-D)	mg/L	0.1	IMAC				< 0.0008
Alachlor	mg/L	0.005	IMAC				< 0.0004
Aldicarb	mg/L	0.009	MAC				< 0.0035
Aldrin + Dieldrin	mg/L	0.0007	MAC				< 0.000006
Atrazine + N-dealkylated metabolites	mg/L	0.005	IMAC				< 0.0002
Azinphos-methyl	mg/L	0.02	MAC				< 0.0003
Bendiocarb	mg/L	0.04	MAC				< 0.003
Benzene	mg/L	0.005	MAC	< 0.0001	< 0.0001	< 0.0001	< 0.0001
Benzo(a)pyrene	mg/L	0.00001	MAC				< 0.00001
Bromoxynil	mg/L	0.005	IMAC				< 0.0004
Carbaryl	mg/L	0.09	MAC				< 0.0002
Carbofuran	mg/L	0.09	MAC				< 0.004
Carbon Tetrachloride	mg/L	0.005	MAC	< 0.0002	< 0.0002	< 0.0002	< 0.0002
Chlordane (Total)	mg/L	0.007	MAC				< 0.000006
Chlorpyrifos	mg/L	0.09	MAC				< 0.0002
Cyanazine	mg/L	0.01	IMAC				< 0.0003
Diazinon	mg/L	0.02	MAC				< 0.0002
Dicamba	mg/L	0.12	MAC				< 0.0004
Dichloromethane	mg/L	0.05	MAC	< 0.0005	< 0.001	< 0.0005	< 0.0005
Diclofop-methyl	mg/L	0.009	MAC				< 0.0004
Dimethoate	mg/L	0.02	IMAC				< 0.0003
Dinoseb	mg/L	0.01	MAC				< 0.0005
Diquat	mg/L	0.07	MAC				< 0.0001
Diuron	mg/L	0.15	MAC				< 0.0002
Glyphosate	mg/L	0.28	IMAC				< 0.002
Heptachlor + Heptachlor Epoxide	mg/L	0.003	MAC				< 0.000008
Lindane	mg/L	0.004	MAC				< 0.000005
Malathion	mg/L	0.19	MAC				< 0.0002
Methoxychlor	mg/L	0.9	MAC				< 0.000009
Metolachlor	mg/L	0.05	IMAC				< 0.0002
Metribuzin	mg/L	0.08	MAC				< 0.0003
Monochlorobenzene	mg/L	0.08	MAC	< 0.0001	< 0.0001	< 0.0001	< 0.0001
Paraquat	mg/L	0.01	IMAC				< 0.0001
Parathion	mg/L	0.05	MAC				< 0.0002



Organics Test Results

Reading	Units	ODWS		22/01/2007	16/04/2007	09/07/2007	22/10/2007
Pentachlorophenol	mg/L	0.06	MAC				< 0.0004
Phorate	mg/L	0.002	IMAC				< 0.0002
Picloram	mg/L	0.19	IMAC				< 0.0007
Polychlorinated Biphenyls (PCBs)	mg/L	0.003	IMAC				< 0.00002
Prometryne	mg/L	0.001	IMAC				< 0.0002
Simazine	mg/L	0.01	IMAC				< 0.0002
Temephos	mg/L	0.28	IMAC				< 0.003
Terbufos	mg/L	0.001	IMAC				< 0.0002
Tetrachloroethylene (perchloroethylene)	mg/L	0.03	MAC	< 0.0003	< 0.0003	< 0.0003	< 0.0003
Triallate	mg/L	0.23	MAC				< 0.002
Trichloroethene	mg/L	0.005	MAC	< 0.0001	< 0.0001	< 0.0001	< 0.0001
Trifluralin	mg/L	0.045	IMAC				< 0.000006
Vinyl Chloride	mg/L	0.002	MAC	< 0.0002	< 0.0002	< 0.0002	< 0.0002

"<": indicates the result is below Method Detection Limit

ODWS: Ontario Drinking Water Standard

MAC: Ontario Drinking Water Standard - Health Related (Maximum Acceptable Concentration)

AO: Ontario Drinking Water Standard - Non Health Related (Aesthetic Objective)

mg/L: milligrams per litre, parts permillion (ppm)



Inorganics Test Results

Reading	Units	ODWS		25/04/2005	18/07/2005
Barium as Ba	mg/L	1	MAC	0.0226	0.0215
Boron as B	mg/L	5	IMAC	0.023	0.022
Mercury as Hg	mg/L	0.001	MAC	< 0.00001	< 0.00001
Uranium as U	mg/L	0.02	MAC	< 0.01	< 0.01

"<": indicates the result is below Method Detection Limit

ODWS: Ontario Drinking Water Standard

MAC: Ontario Drinking Water Standard - Health Related (Maximum Acceptable Concentration)

AO: Ontario Drinking Water Standard - Non Health Related (Aesthetic Objective)

mg/L: milligrams per litre, parts permillion (ppm)