

Part III Form 2
Section 11. ANNUAL REPORT.

Drinking-Water System Number:	210003280
Drinking-Water System Name:	Keswick Water Supply System
Drinking-Water System Owner:	Regional Municipality of York
Drinking-Water System Category:	Large Municipal Residential
Period being reported:	January 1, 2007 to December 31, 2007

<p><u>Complete if your Category is Large Municipal Residential or Small Municipal Residential</u></p> <p>Does your Drinking-Water System serve more than 10,000 people? Yes [X] No []</p> <p>Is your annual report available to the public at no charge on a web site on the Internet? Yes [X] No []</p> <p>Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.</p> <div style="border: 1px solid black; padding: 5px;"> <p>Regional Municipality of York Administrative Building Transportation and Works Department 17250 Yonge Street Newmarket, Ontario</p> </div>	<p><u>Complete for all other Categories.</u></p> <p>Number of Designated Facilities served: <input type="text"/></p> <p>Did you provide a copy of your annual report to all Designated Facilities you serve? Yes [] No []</p> <p>Number of Interested Authorities you report to: <input type="text"/></p> <p>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? Yes [] No []</p>
---	---

Note: For the following tables below, additional rows or columns may be added or an appendix may be attached to the report

List all Drinking-Water Systems (if any), which receive all of their drinking water from your system:

Drinking Water System Name	Drinking Water System Number
Town of Georgina, Keswick and Sutton Water Distribution	260062686

Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water? Yes [X] No []

Indicate how you notified system users that your annual report is available, and is free of charge.

Public access/notice via the web

Public access/notice via Government Office

Public access/notice via a newspaper

Public access/notice via Public Request

Public access/notice via a Public Library

Public access/notice via other method _____

Describe your Drinking-Water System

York Region operates a water treatment plant in the community of Keswick, along Cook's Bay. The Keswick Water Treatment Plant draws water from Cook's Bay in Lake Simcoe to supply a predominantly residential population.

The Keswick Water Treatment Plant was constructed between, 1982-1983. The 600-millimetre diameter water pipe extends 365 metres out into Cook's Bay and draws water from a depth of 8.5 metres. At certain times of the year, when the incoming water rises above 12 degrees Celsius, chlorine is added at the intake to limit Zebra Mussel growth.

The incoming water is initially screened to remove large objects. The water is chemically treated with a coagulant mixed in the riser pipe prior to the flocculation tanks (a coagulant is used to make suspended particles clump together and eventually settle out during the treatment process). The water moves through sedimentation tank, where settling occurs, and is then filtered by dual media gravity filters. The filters contained granular activated carbon, which removes taste and odour in the water. The water continues to the clearwell and ground reservoir located on the plant site.

The filtered water is disinfected using chlorine and is then pumped to distribution system by the high lift pumps. Fluoride is also added to the water at the Keswick Water Treatment Plant.

Treatment processes throughout the plant are monitored by on-line analyzers. The analyzers are equipped with alarms, which alert operational staff of conditions that require attention.

There is one point of entry from the Keswick Water Treatment Plant to the distribution system servicing the community. The Keswick water treatment plant has the ability to be feed into the same system as Georgina or independently of Georgina based on the mode of operation. Two storage tanks are available in Keswick.

The Township of Keswick owns and operates the distribution system that delivers the water from the regional watermains to the homes in Keswick.

List all water treatment chemicals used over this reporting period

Chlorine Gas
Hydrofluosilicic Acid

Polyhydroxyaluminum Chloride (PAC)
Carbon Dioxide

Were any significant expenses incurred to?

- Install required equipment
- Repair required equipment
- Replace required equipment

Please provide a brief description and a breakdown of monetary expenses incurred

Some of the following expenditures represent only part of the total project cost.

Keswick North Elevation Tank	\$104,768
Woodbine Ravenshoe Water Main	\$288,852
Georgina Water Treatment Plant	\$271,091
Metro Road Water Main Water Treatment Plant to Woodbine	\$950,859
Keswick Pumping Station Upgrades	\$78,386
Keswick Water Treatment Plant – Noise Issues	\$36,500

Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre

Incident Date	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date
April 30, 2007	Mercury	1.38	Ug/L	Resample collected May 14, 2007. Results received May 18, 2007 = <0.01 ug/L. Results were communicated to SAC and Dept. of Health	May 18, 2007
April 30, 2007	Sodium	25	mg/L	Resample received June 1, 2007 and informed SAC and Dept. of Health of results of resample.	June 1, 2007

Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.

	Number of Samples	Range of E.Coli Or Fecal Results (min #)-(max #)	Range of Total Coliform Results (min #)-(max #)	Number of HPC Samples	Range of HPC Results (min #)-(max #)
Raw	52	0-1	0-42		
Treated	53	0	0	52	0-32
Distribution					

Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.

	Number of Grab Samples	Range of Results (min #)-(max #)
Turbidity Treated	8760	0.030 – 0.681

NOTE: For continuous monitors use 8760 as the number of samples.

Chlorine	8760	0.601 – 3.266
Fluoride (If the DWS provides fluoridation)	8760	0.200 – 0.936

NOTE: Record the unit of measure if it is **not** milligrams per litre.

Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument.

Date of legal instrument issued	Parameter	Date Sampled	Result	Unit of Measure

Summary of Inorganic parameters tested during this reporting period or the most recent sample results

Note: See attached results for Inorganic parameters

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony				
Arsenic				
Barium				
Boron				
Cadmium				
Chromium				
Lead				
Mercury				
Selenium				
Sodium				
Uranium				
Fluoride				
Nitrite				
Nitrate				

Summary of Organic parameters sampled during this reporting period or the most recent sample results

Note: See attached results for Organic parameters (THM value in table below)

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor				
Aldicarb				
Aldrin + Dieldrin				

Atrazine + N-dealkylated metabolites				
Azinphos-methyl				
Bendiocarb				
Benzene				
Benzo(a)pyrene				
Bromoxynil				
Carbaryl				
Carbofuran				
Carbon Tetrachloride				
Chlordane (Total)				
Chlorpyrifos				
Cyanazine				
Diazinon				
Dicamba				
1,2-Dichlorobenzene				
1,4-Dichlorobenzene				
Dichlorodiphenyltrichloroethane (DDT) + metabolites				
1,2-Dichloroethane				
1,1-Dichloroethylene (vinylidene chloride)				
Dichloromethane				
2-4 Dichlorophenol				
2,4-Dichlorophenoxy acetic acid (2,4-D)				
Diclofop-methyl				
Dimethoate				
Dinoseb				
Diquat				
Diuron				
Glyphosate				
Heptachlor + Heptachlor Epoxide				
Lindane (Total)				
Malathion				
Methoxychlor				
Metolachlor				
Metribuzin				
Monochlorobenzene				
Paraquat				
Parathion				
Pentachlorophenol				
Phorate				
Picloram				
Polychlorinated Biphenyls(PCB)				
Prometryne				

Simazine				
THM (NOTE: show latest annual average) Keswick WTP Clearwell		0.036	Mg/L	
Temephos				
Terbufos				
Tetrachloroethylene				
2,3,4,6-Tetrachlorophenol				
Triallate				
Trichloroethylene				
2,4,6-Trichlorophenol				
2,4,5-Trichlorophenoxy acetic acid (2,4,5-T)				
Trifluralin				
Vinyl Chloride				

York Region monitors another group of disinfection by-products called haloacetic acids (HAAs). There are no limits set for HAAs in Ontario Drinking Water Standards.

Reading Name	Keswick WTP Clearwell Mg/L April 30
Bromochloroacetic acid	< 0.004
Dibromoacetic acid	< 0.004
Dichloroacetic acid	0.01
Monobromoacetic acid	< 0.004
Monochloroacetic acid	< 0.035
Trichloroacetic acid	0.012

“<” indicates the result is below the Method Detection Limit

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

Parameter	Result Value	Unit of Measure	Date of Sample
Mercury as Hg	0.00138	Mg/L	30/04/2007
Lead as Pb	0.0113	Mg/L	10/03/2007

(Only if DWS category is large municipal residential, small municipal residential, large municipal non residential, non municipal year round residential, large non municipal non residential)



Inorganics Test Results

Reading	Units	ODWS		29/01/2007	30/04/2007	23/07/2007	15/10/2007
Antimony as Sb	mg/L	0.006	IMAC	< 0.0004	< 0.0004	< 0.0004	0.0003
Arsenic as As	mg/L	0.025	IMAC	< 0.0004	< 0.0004	< 0.0004	0.0006
Barium as Ba	mg/L	1	MAC	0.0327	0.0325		
Boron as B	mg/L	5	IMAC	0.018	0.019		
Cadmium as Cd	mg/L	0.005	MAC	0.0001	0.0001	0.0001	< 0.0001
Chromium as Cr	mg/L	0.05	MAC	< 0.0003	< 0.0003	< 0.0003	< 0.0001
Fluoride as F	mg/L	0.8	MAC	0.45	0.21	0.35	0.47
Lead as Pb	mg/L	0.01	MAC	< 0.0007	< 0.0007	< 0.0007	< 0.0001
Mercury as Hg	mg/L	0.001	MAC	< 0.00001	0.00138		
Nitrate as N	mg/L	10	MAC	0.41	0.23	0.1	0.2
Nitrite	mg/L	1	MAC	< 0.02	< 0.02	< 0.02	< 0.002
Selenium as Se	mg/L	0.01	MAC	< 0.002	< 0.002	< 0.002	< 0.0001
Sodium as Na	mg/L	200	AO	25.7	25	22.4	22.3
Uranium as U	mg/L	0.02	MAC	< 0.002	< 0.002		

"<": indicates the result is below Method Detection Limit
 ODWS: Ontario Drinking Water Standard
 MAC: Ontario Drinking Water Standard - Health Related (Maximum Acceptable Concentration)
 AO: Ontario Drinking Water Standard - Non Health Related (Aesthetic Objective)
 mg/L: milligrams per litre, parts permillion (ppm)



Organics Test Results

Reading	Units	ODWS	29/01/2007	30/04/2007	02/05/2007	23/07/2007	15/10/2007
(DDT) + Metabolites	mg/L	0.03	MAC	< 0.000008			
1,1-dichloroethylene (vinylidene chloride)	mg/L	0.014	MAC	< 0.0003	< 0.0003	< 0.0003	< 0.0003
1,2-(o-dcb) Dichlorobenzene	mg/L	0.2	MAC	< 0.0001	< 0.0001	< 0.0001	< 0.0001
1,2-Dichloroethane	mg/L	0.005	IMAC	< 0.0001	< 0.0001	< 0.0001	< 0.0001
1,4-(p-dcb) Dichlorobenzene	mg/L	0.005	MAC	< 0.0001	< 0.0001	< 0.0001	< 0.0001
2,3,4,6-Tetrachlorophenol	mg/L	0.1	MAC	< 0.0005			
2,4,5-trichlorophenoxyacetic acid (2,4,5-T)	mg/L	0.28	MAC	< 0.0005			
2,4,6-Trichlorophenol	mg/L	0.005	MAC	< 0.0005			
2,4-Dichlorophenol	mg/L	0.9	MAC	< 0.0004			
2,4-dichlorophenoxyacetic acid (2,4-D)	mg/L	0.1	IMAC	< 0.0008			
Alachlor	mg/L	0.005	IMAC	< 0.0004			
Aldicarb	mg/L	0.009	MAC	< 0.0035			
Aldrin + Dieldrin	mg/L	0.0007	MAC	< 0.000006			
Atrazine + N-dealkylated metabolites	mg/L	0.005	IMAC	< 0.0001			
Bendiocarb	mg/L	0.04	MAC	< 0.003			
Benzene	mg/L	0.005	MAC	< 0.0001	< 0.0001	< 0.0001	< 0.0001
Benzo(a)pyrene	mg/L	0.00001	MAC	< 0.00001			
Bromoxynil	mg/L	0.005	IMAC	< 0.0004			
Carbaryl	mg/L	0.09	MAC	< 0.0002			
Carbofuran	mg/L	0.09	MAC	< 0.004			
Carbon Tetrachloride	mg/L	0.005	MAC	< 0.0002	< 0.0002	< 0.0002	< 0.0002
Chlordane (Total)	mg/L	0.007	MAC	< 0.000006			
Cyanazine	mg/L	0.01	IMAC	< 0.0002			
Dicamba	mg/L	0.12	MAC	< 0.0004			
Dichloromethane	mg/L	0.05	MAC	< 0.0005	< 0.001	< 0.0005	< 0.0005
Diclofop-methyl	mg/L	0.009	MAC	< 0.0004			
Dinoseb	mg/L	0.01	MAC	< 0.0005			
Diquat	mg/L	0.07	MAC	< 0.0001			
Diuron	mg/L	0.15	MAC	< 0.0004			
Glyphosate	mg/L	0.28	IMAC		< 0.002		
Heptachlor + Heptachlor Epoxide	mg/L	0.003	MAC	< 0.000008			
Lindane	mg/L	0.004	MAC	< 0.000005			
Methoxychlor	mg/L	0.9	MAC	< 0.000009			
Metolachlor	mg/L	0.05	IMAC	< 0.0002			
Metribuzin	mg/L	0.08	MAC	< 0.00008			
Monochlorobenzene	mg/L	0.08	MAC	< 0.0001	< 0.0001	< 0.0001	< 0.0001
Paraquat	mg/L	0.01	IMAC	< 0.0001			
Pentachlorophenol	mg/L	0.06	MAC	< 0.0004			
Picloram	mg/L	0.19	IMAC	< 0.0007			
Polychlorinated Biphenyls (PCBs)	mg/L	0.003	IMAC	< 0.00002			
Prometryne	mg/L	0.001	IMAC	< 0.00008			
Simazine	mg/L	0.01	IMAC	< 0.00008			
Tetrachloroethylene (perchloroethylene)	mg/L	0.03	MAC	< 0.0003	< 0.0003	< 0.0003	< 0.0003



Organics Test Results

Reading	Units	ODWS		29/01/2007	30/04/2007	02/05/2007	23/07/2007	15/10/2007
Triallate	mg/L	0.23	MAC		< 0.002			
Trichloroethene	mg/L	0.005	MAC	< 0.0001	< 0.0001		< 0.0001	< 0.0001
Trifluralin	mg/L	0.045	IMAC		< 0.000006			
Vinyl Chloride	mg/L	0.002	MAC	< 0.0002	< 0.0002		< 0.0002	< 0.0002

"<": indicates the result is below Method Detection Limit

ODWS: Ontario Drinking Water Standard

MAC: Ontario Drinking Water Standard - Health Related (Maximum Acceptable Concentration)

AO: Ontario Drinking Water Standard - Non Health Related (Aesthetic Objective)

mg/L: milligrams per litre, parts permillion (ppm)



Organics Test Results

Reading	Units	ODWS		24/04/2006
Azinphos-methyl	mg/L	0.02	MAC	< 0.0002
Chlorpyrifos	mg/L	0.09	MAC	< 0.0002
Chlorpyrifos-methyl (Reldan)	mg/L	0.09	MAC	< 0.0002
Diazinon	mg/L	0.02	MAC	< 0.0002
Dimethoate	mg/L	0.02	IMAC	< 0.0003
Malathion	mg/L	0.19	MAC	< 0.0002
Parathion	mg/L	0.05	MAC	< 0.0002
Phorate	mg/L	0.002	IMAC	< 0.0002
Temephos	mg/L	0.28	IMAC	< 0.003
Terbufos	mg/L	0.001	IMAC	< 0.0002

"<": indicates the result is below Method Detection Limit

ODWS: Ontario Drinking Water Standard

MAC: Ontario Drinking Water Standard - Health Related (Maximum Acceptable Concentration)

AO: Ontario Drinking Water Standard - Non Health Related (Aesthetic Objective)

mg/L: milligrams per litre, parts permillion (ppm)