



# Ontario Drinking-Water Systems Regulation O. Reg. 170/03

## OPTIONAL ANNUAL REPORT TEMPLATE.

<b>Drinking-Water System Number:</b>	220004046
<b>Drinking-Water System Name:</b>	York Drinking Water System - Holland Landing
<b>Drinking-Water System Owner:</b>	Regional Municipality of York
<b>Drinking-Water System Category:</b>	Large Municipal Residential
<b>Period being reported:</b>	January 1, 2010 to December 31, 2010

<p><b><u>Complete if your Category is Large Municipal Residential or Small Municipal Residential</u></b></p> <p>Does your Drinking-Water System serve more than 10,000 people? Yes [ ] No [X]</p> <p>Is your annual report available to the public at no charge on a web site on the Internet? Yes [X] No [ ]</p> <p>Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.</p> <div style="border: 1px solid black; padding: 5px;"> <p>Regional Municipality of York Administrative Building Environmental Services Department 17250 Yonge Street, Newmarket, Ontario</p> </div>	<p><b><u>Complete for all other Categories.</u></b></p> <p>Number of Designated Facilities served: <input type="text"/></p> <p>Did you provide a copy of your annual report to all Designated Facilities you serve? Yes [ ] No [ ]</p> <p>Number of Interested Authorities you report to: <input type="text"/></p> <p>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? Yes [ ] No [ ]</p>
--	---

**Note: For the following tables below, additional rows or columns may be added or an appendix may be attached to the report**

List all Drinking-Water Systems (if any), which receive all of their drinking water from your system:

Drinking Water System Name	Drinking Water System Number
Holland-Queensville-Sharon Distribution System	260001747

Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water? Yes [X] No [ ]



**Indicate how you notified system users that your annual report is available, and is free of charge.**

**Public access/notice via the web**

**Public access/notice via Government Office**

**Public access/notice via a newspaper**

**Public access/notice via Public Request**

**Public access/notice via a Public Library**

**Public access/notice via other method** \_\_\_\_\_

**Describe your Drinking-Water System**

York Region operates two production wells servicing the community of Holland Landing in the Town of East Gwillimbury. The Holland Landing wells draw water from the Yonge Street Aquifer which is also the source of water for the Town of Newmarket and the Town of Aurora.

Water withdrawal from each of the wells is regulated by a Permit to Take Water, issued by the Ministry of the Environment for the Yonge Street Aquifer as a whole. York Region is continuing to work to improve our understanding of the Yonge Street Aquifer and the effects of water taking through detailed hydrogeological studies, numerical modeling analysis and an extensive monitoring program.

Chloramination (adding chlorine and ammonia) is the disinfection process used for the Holland Landing production wells. Sodium silicate is added to the water following chloramination to reduce the potential for iron to stain plumbing fixtures and laundry in the serviced area.

Following treatment, water enters the Holland Landing distribution system from two points: Well #1 and Well #2. There are two storage facilities servicing the community of Holland Landing. There is a back up water supply to the community from the Queensville Well Supply System.

York Region is the wholesale supplier of water to the community of Holland Landing and is responsible for the supply, production, treatment and storage of water. The Town of East Gwillimbury owns and operates the distribution system that delivers the water from the Regional watermains to homes in the community of Holland Landing.

**List all water treatment chemicals used over this reporting period**

Chlorine Gas  
Sodium Silicate  
Ammonia Sulphate

**Were any significant expenses incurred to?**

- Install required equipment
- Repair required equipment
- Replace required equipment

Please provide a brief description and a breakdown of monetary expenses incurred  
Some of the following expenditures represent only part of the total project costs.

Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre

Incident Date	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date

Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.

	Number of Samples	Range of E.Coli Or Fecal Results (min #)-(max #)	Range of Total Coliform Results (min #)-(max #)	Number of HPC Samples	Range of HPC Results (min #)-(max #)
Raw	80	0	0		
Treated	80	0	0	80	1-150
Distribution					

Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.

	Number of Grab Samples	Range of Results (min #)-(max #)
Turbidity (Treated)	8760	0.018 – 4.049
Turbidity (Raw)	20	0.24 – 0.63
Chlorine	8760	0.282 – 3.184
Fluoride (If the DWS provides fluoridation)		

*NOTE: For continuous monitors use 8760 as the number of samples.*

*NOTE: Record the unit of measure if it is not milligrams per litre.*

Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument.

Date of legal instrument issued	Parameter	Date Sampled	Result	Unit of Measure

**Summary of Inorganic parameters tested during this reporting period or the most recent sample results**

**Note: See attached results for Inorganic parameters**

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony				
Arsenic				
Barium				
Boron				
Cadmium				
Chromium				
Lead				
Mercury				
Selenium				
Sodium				
Uranium				
Fluoride				
Nitrite				
Nitrate				

**Summary of lead testing under Schedule 15.1 during this reporting period**

(applicable to the following drinking water systems; large municipal residential systems, small municipal residential systems, and non-municipal year-round residential systems)

Location Type	Number of Samples	Range of Lead Results (min#) – (max #)	Number of Exceedances
Plumbing			
Distribution			

**Summary of Organic parameters sampled during this reporting period or the most recent sample results**

**Note: See attached results for Organic parameters (THM values in table below)**

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor				
Aldicarb				
Aldrin + Dieldrin				
Atrazine + N-dealkylated metabolites				
Azinphos-methyl				



<b>Bendiocarb</b>				
<b>Benzene</b>				
<b>Benzo(a)pyrene</b>				
<b>Bromoxynil</b>				
<b>Carbaryl</b>				
<b>Carbofuran</b>				
<b>Carbon Tetrachloride</b>				
<b>Chlordane (Total)</b>				
<b>Chlorpyrifos</b>				
<b>Cyanazine</b>				
<b>Diazinon</b>				
<b>Dicamba</b>				
<b>1,2-Dichlorobenzene</b>				
<b>1,4-Dichlorobenzene</b>				
<b>Dichlorodiphenyltrichloroethane (DDT) + metabolites</b>				
<b>1,2-Dichloroethane</b>				
<b>1,1-Dichloroethylene (vinylidene chloride)</b>				
<b>Dichloromethane</b>				
<b>2-4 Dichlorophenol</b>				
<b>2,4-Dichlorophenoxy acetic acid (2,4-D)</b>				
<b>Diclofop-methyl</b>				
<b>Dimethoate</b>				
<b>Dinoseb</b>				
<b>Diquat</b>				
<b>Diuron</b>				
<b>Glyphosate</b>				
<b>Heptachlor + Heptachlor Epoxide</b>				
<b>Lindane (Total)</b>				
<b>Malathion</b>				
<b>Methoxychlor</b>				
<b>Metolachlor</b>				
<b>Metribuzin</b>				
<b>Monochlorobenzene</b>				
<b>Paraquat</b>				
<b>Parathion</b>				
<b>Pentachlorophenol</b>				
<b>Phorate</b>				
<b>Picloram</b>				
<b>Polychlorinated Biphenyls(PCB)</b>				
<b>Prometryne</b>				
<b>Simazine</b>				

<b>THM</b> (NOTE: show latest annual average)		0.009	Mg/L	
<b>Well #1</b>		0.015	Mg/L	
<b>Well #2</b>				
<b>Temephos</b>				
<b>Terbufos</b>				
<b>Tetrachloroethylene</b>				
<b>2,3,4,6-Tetrachlorophenol</b>				
<b>Triallate</b>				
<b>Trichloroethylene</b>				
<b>2,4,6-Trichlorophenol</b>				
<b>2,4,5-Trichlorophenoxy acetic acid (2,4,5-T)</b>				
<b>Trifluralin</b>				
<b>Vinyl Chloride</b>				

**York Region monitors another group of disinfection by-products called haloacetic acids (HAAs). There are no limits set for HAAs in Ontario Drinking Water Standards.**

<b>Haloacetic acid</b>	<b>Well #1 Mg/L June 30</b>	<b>Well #2 Mg/L June 30</b>
<b>Bromochloroacetic acid</b>	0.004	0.004
<b>Dibromoacetic acid</b>	0.004	0.004
<b>Dichloroacetic acid</b>	0.004	0.005
<b>Monobromoacetic acid</b>	0.004	0.004
<b>Monochloroacetic acid</b>	0.02	0.02
<b>Trichloroacetic acid</b>	0.004	0.007

“<” indicates the result is below the Method Detection Limit

**List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.**

<b>Parameter</b>	<b>Result Value</b>	<b>Unit of Measure</b>	<b>Date of Sample</b>

**(Only if DWS category is large municipal residential, small municipal residential, large municipal non residential, non municipal year round residential, large non municipal non residential)**



Inorganics Test Results

Reading	Units	ODWS		18/01/2010	21/07/2010	25/10/2010
Antimony as Sb	mg/L	0.006	IMAC	0.0004	0.0004	0.0006
Arsenic as As	mg/L	0.025	IMAC	0.0002	0.0001	0.0003
Cadmium as Cd	mg/L	0.005	MAC	0.0001	< 0.0001	< 0.0001
Chromium as Cr	mg/L	0.05	MAC	< 0.0001	< 0.0001	< 0.0001
Fluoride as F	mg/L	1.5	MAC	0.214	0.19	0.19
Lead as Pb	mg/L	0.01	MAC	0.0001	0.0001	0.0007
Nitrate + Nitrite as N	mg/L	10	MAC	0.02	0.027	0.027
Nitrate as N	mg/L	10	MAC	0.011	0.007	0.006
Nitrite	mg/L	1	MAC	0.007	0.02	0.021
Selenium as Se	mg/L	0.01	MAC	0.0005	0.0001	0.0003
Sodium as Na	mg/L	200	AO	22.7	21.2	20.8

"<": indicates the result is below Method Detection Limit

ODWS: Ontario Drinking Water Standard

MAC: Ontario Drinking Water Standard - Health Related (Maximum Acceptable Concentration)

AO: Ontario Drinking Water Standard - Non Health Related (Aesthetic Objective)

mg/L: milligrams per litre, parts permillion (ppm)



Organics Test Results

Reading	Units	ODWS	18/01/2010	21/07/2010	11/08/2010	25/10/2010
(DDT) + Metabolites	mg/L	0.03	MAC	< 0.000008		
1,1-dichloroethylene (vinylidene chloride)	mg/L	0.014	MAC	< 0.0003	< 0.0003	< 0.0003
1,2-(o-dcb) Dichlorobenzene	mg/L	0.2	MAC	< 0.0001	< 0.0001	< 0.0001
1,2-Dichloroethane	mg/L	0.005	IMAC	< 0.0001	< 0.0001	< 0.0001
1,4-(p-dcb) Dichlorobenzene	mg/L	0.005	MAC	< 0.0001	< 0.0001	< 0.0001
2,3,4,6-Tetrachlorophenol	mg/L	0.1	MAC		< 0.0005	
2,4,5-trichlorophenoxyacetic acid (2,4,5-T)	mg/L	0.28	MAC		< 0.0005	
2,4,6-Trichlorophenol	mg/L	0.005	MAC		< 0.0005	
2,4-Dichlorophenol	mg/L	0.9	MAC		< 0.0007	
2,4-dichlorophenoxyacetic acid (2,4-D)	mg/L	0.1	IMAC		< 0.0008	
Alachlor	mg/L	0.005	IMAC		< 0.0004	
Aldicarb	mg/L	0.009	MAC			< 0.0045
Aldrin + Dieldrin	mg/L	0.0007	MAC		< 0.000006	
Atrazine + N-dealkylated metabolites	mg/L	0.005	IMAC		< 0.0002	
Azinphos-methyl	mg/L	0.02	MAC		< 0.0003	
Bendiocarb	mg/L	0.04	MAC			< 0.003
Benzene	mg/L	0.005	MAC	< 0.0001	< 0.0001	< 0.0001
Benzo(a)pyrene	mg/L	0.00001	MAC		< 0.00001	
Bromoxynil	mg/L	0.005	IMAC		< 0.0004	
Carbaryl	mg/L	0.09	MAC			< 0.003
Carbofuran	mg/L	0.09	MAC			< 0.003
Carbon Tetrachloride	mg/L	0.005	MAC	< 0.0002	< 0.0002	< 0.0002
Chlordane (Total)	mg/L	0.007	MAC		< 0.000006	
Chlorpyrifos	mg/L	0.09	MAC		< 0.0002	
Cyanazine	mg/L	0.01	IMAC		< 0.0003	
Diazinon	mg/L	0.02	MAC		< 0.0002	
Dicamba	mg/L	0.12	MAC		< 0.0004	
Dichloromethane	mg/L	0.05	MAC	< 0.0005	< 0.0005	< 0.0005
Diclofop-methyl	mg/L	0.009	MAC		< 0.0004	
Dimethoate	mg/L	0.02	IMAC		< 0.0003	
Dinoseb	mg/L	0.01	MAC		< 0.0005	
Diquat	mg/L	0.07	MAC			< 0.001
Diuron	mg/L	0.15	MAC			< 0.003
Glyphosate	mg/L	0.28	IMAC			< 0.025
Heptachlor + Heptachlor Epoxide	mg/L	0.003	MAC		< 0.000008	
Lindane	mg/L	0.004	MAC		< 0.000005	
Malathion	mg/L	0.19	MAC		< 0.0002	
Methoxychlor	mg/L	0.9	MAC		< 0.000009	
Metolachlor	mg/L	0.05	IMAC		< 0.0002	
Metribuzin	mg/L	0.08	MAC		< 0.0003	
Monochlorobenzene	mg/L	0.08	MAC	< 0.0001	< 0.0001	< 0.0001
Paraquat	mg/L	0.01	IMAC			< 0.001
Parathion	mg/L	0.05	MAC		< 0.0002	



Organics Test Results

Reading	Units	ODWS		18/01/2010	21/07/2010	11/08/2010	25/10/2010
Pentachlorophenol	mg/L	0.06	MAC		< 0.0004		
Phorate	mg/L	0.002	IMAC		< 0.0002		
Picloram	mg/L	0.19	IMAC		< 0.0007		
Polychlorinated Biphenyls (PCBs)	mg/L	0.003	IMAC		< 0.00002		
Prometryne	mg/L	0.001	IMAC		< 0.0002		
Simazine	mg/L	0.01	IMAC		< 0.0002		
Temephos	mg/L	0.28	IMAC		< 0.003		
Terbufos	mg/L	0.001	IMAC		< 0.0002		
Tetrachloroethylene (perchloroethylene)	mg/L	0.03	MAC	< 0.0003	< 0.0003		< 0.0003
Triallate	mg/L	0.23	MAC			< 0.004	
Trichloroethene	mg/L	0.005	MAC	< 0.0001	< 0.0001		< 0.0001
Trifluralin	mg/L	0.045	IMAC		< 0.000006		
Vinyl Chloride	mg/L	0.002	MAC	< 0.0002	< 0.0002		< 0.0002

"<": indicates the result is below Method Detection Limit

ODWS: Ontario Drinking Water Standard

MAC: Ontario Drinking Water Standard - Health Related (Maximum Acceptable Concentration)

AO: Ontario Drinking Water Standard - Non Health Related (Aesthetic Objective)

mg/L: milligrams per litre, parts permillion (ppm)



Inorganics Test Results

Reading	Units	ODWS		18/01/2010	12/04/2010	21/07/2010	25/10/2010
Antimony as Sb	mg/L	0.006	IMAC	0.0005	0.0002	0.0004	0.0006
Arsenic as As	mg/L	0.025	IMAC	0.0002	0.0002	0.0001	0.0001
Barium as Ba	mg/L	1	MAC		0.198		
Boron as B	mg/L	5	IMAC		0.062		
Cadmium as Cd	mg/L	0.005	MAC	< 0.0001	< 0.0001	< 0.0001	< 0.0001
Chromium as Cr	mg/L	0.05	MAC	< 0.0001	< 0.0001	< 0.0001	< 0.0001
Fluoride as F	mg/L	1.5	MAC	0.238	0.2	0.18	0.21
Lead as Pb	mg/L	0.01	MAC	0.0001	0.0001	< 0.0001	< 0.0001
Mercury as Hg	mg/L	0.001	MAC		< 0.00002		
Nitrate + Nitrite as N	mg/L	10	MAC	0.02	0.04	0.037	0.035
Nitrate as N	mg/L	10	MAC	0.013	0.021	0.015	0.013
Nitrite	mg/L	1	MAC	0.009	0.021	0.022	0.022
Selenium as Se	mg/L	0.01	MAC	0.0005	< 0.0001	0.0001	0.0002
Sodium as Na	mg/L	200	AO	23.7	22.9	23.1	21.8
Uranium as U	mg/L	0.02	MAC		< 0.0001		

"<": indicates the result is below Method Detection Limit  
 ODWS: Ontario Drinking Water Standard  
 MAC: Ontario Drinking Water Standard - Health Related (Maximum Acceptable Concentration)  
 AO: Ontario Drinking Water Standard - Non Health Related (Aesthetic Objective)  
 mg/L: milligrams per litre, parts permillion (ppm)



Organics Test Results

Reading	Units	ODWS	18/01/2010	12/04/2010	21/07/2010	11/08/2010	26/08/2010	25/10/2010
(DDT) + Metabolites	mg/L	0.03	MAC		< 0.000008			
1,1-dichloroethylene (vinylidene chloride)	mg/L	0.014	MAC	< 0.0003	< 0.0003	< 0.0003		< 0.0003
1,2-(o-dcb) Dichlorobenzene	mg/L	0.2	MAC	< 0.0001	< 0.0001	< 0.0001		< 0.0001
1,2-Dichloroethane	mg/L	0.005	IMAC	< 0.0001	< 0.0001	< 0.0001		< 0.0001
1,4-(p-dcb) Dichlorobenzene	mg/L	0.005	MAC	< 0.0001	< 0.0001	< 0.0001		< 0.0001
2,3,4,6-Tetrachlorophenol	mg/L	0.1	MAC				< 0.0005	
2,4,5-trichlorophenoxyacetic acid (2,4,5-T)	mg/L	0.28	MAC				< 0.0005	
2,4,6-Trichlorophenol	mg/L	0.005	MAC				< 0.0005	
2,4-Dichlorophenol	mg/L	0.9	MAC				< 0.0007	
2,4-dichlorophenoxyacetic acid (2,4-D)	mg/L	0.1	IMAC				< 0.0008	
Alachlor	mg/L	0.005	IMAC		< 0.0004			
Aldicarb	mg/L	0.009	MAC			< 0.0045		
Aldrin + Dieldrin	mg/L	0.0007	MAC		< 0.000006			
Atrazine + N-dealkylated metabolites	mg/L	0.005	IMAC		< 0.0002			
Azinphos-methyl	mg/L	0.02	MAC		< 0.0003			
Bendiocarb	mg/L	0.04	MAC			< 0.003		
Benzene	mg/L	0.005	MAC	< 0.0001	< 0.0001	< 0.0001		< 0.0001
Benzo(a)pyrene	mg/L	0.00001	MAC		< 0.00001			
Bromoxynil	mg/L	0.005	IMAC				< 0.0004	
Carbaryl	mg/L	0.09	MAC			< 0.003		
Carbofuran	mg/L	0.09	MAC			< 0.003		
Carbon Tetrachloride	mg/L	0.005	MAC	< 0.0002	< 0.0002	< 0.0002		< 0.0002
Chlordane (Total)	mg/L	0.007	MAC		< 0.000006			
Chlorpyrifos	mg/L	0.09	MAC		< 0.0002			
Cyanazine	mg/L	0.01	IMAC		< 0.0003			
Diazinon	mg/L	0.02	MAC		< 0.0002			
Dicamba	mg/L	0.12	MAC				< 0.0004	
Dichloromethane	mg/L	0.05	MAC	< 0.0005	< 0.0005	< 0.0005		< 0.0005
Diclofop-methyl	mg/L	0.009	MAC				< 0.0004	
Dimethoate	mg/L	0.02	IMAC		< 0.0003			
Dinoseb	mg/L	0.01	MAC				< 0.0005	
Diquat	mg/L	0.07	MAC			< 0.001		
Diuron	mg/L	0.15	MAC			< 0.003		
Glyphosate	mg/L	0.28	IMAC			< 0.025		
Heptachlor + Heptachlor Epoxide	mg/L	0.003	MAC		< 0.000008			
Lindane	mg/L	0.004	MAC		< 0.000005			
Malathion	mg/L	0.19	MAC		< 0.0002			
Methoxychlor	mg/L	0.9	MAC		< 0.000009			
Metolachlor	mg/L	0.05	IMAC		< 0.0002			
Metribuzin	mg/L	0.08	MAC		< 0.0003			
Monochlorobenzene	mg/L	0.08	MAC	< 0.0001	< 0.0001	< 0.0001		< 0.0001
Paraquat	mg/L	0.01	IMAC			< 0.001		
Parathion	mg/L	0.05	MAC		< 0.0002			



Organics Test Results

Reading	Units	ODWS		18/01/2010	12/04/2010	21/07/2010	11/08/2010	26/08/2010	25/10/2010
Pentachlorophenol	mg/L	0.06	MAC					< 0.0004	
Phorate	mg/L	0.002	IMAC			< 0.0002			
Picloram	mg/L	0.19	IMAC					< 0.0007	
Polychlorinated Biphenyls (PCBs)	mg/L	0.003	IMAC			< 0.00002			
Prometryne	mg/L	0.001	IMAC			< 0.0002			
Simazine	mg/L	0.01	IMAC			< 0.0002			
Temephos	mg/L	0.28	IMAC			< 0.003			
Terbufos	mg/L	0.001	IMAC			< 0.0002			
Tetrachloroethylene (perchloroethylene)	mg/L	0.03	MAC	< 0.0003	< 0.0003	< 0.0003			< 0.0003
Triallate	mg/L	0.23	MAC				< 0.004		
Trichloroethene	mg/L	0.005	MAC	< 0.0001	< 0.0001	< 0.0001			< 0.0001
Trifluralin	mg/L	0.045	IMAC			< 0.000006			
Vinyl Chloride	mg/L	0.002	MAC	< 0.0002	< 0.0002	< 0.0002			< 0.0002

"<": indicates the result is below Method Detection Limit

ODWS: Ontario Drinking Water Standard

MAC: Ontario Drinking Water Standard - Health Related (Maximum Acceptable Concentration)

AO: Ontario Drinking Water Standard - Non Health Related (Aesthetic Objective)

mg/L: milligrams per litre, parts permillion (ppm)