



The Regional Municipality of York

**Odour Management and Mitigation
(Condition 9) and Ambient Air
Monitoring and Reporting (Condition 11)
Annual Report (EA File No. 02-04-03)**

Prepared by:

AECOM
105 Commerce Valley Drive West, Floor 7
Markham, ON, Canada L3T 7W3
www.aecom.com

905 886 7022 tel
905 886 9494 fax

July, 2018

Project Number: 60163719

Executive Summary

The Southeast Collector (SEC) Trunk Sewer system conveys municipal wastewater 15 kilometres from the intersection of Ninth Line and Rouge Bank Drive in Markham, Ontario, to the intersection of Finch Avenue and Valley Farm Road in Pickering, Ontario. The operation of the system accommodates future growth in York Region and provides additional capacity for peak and extraneous flows. Furthermore, it increases redundancy to the existing York Durham Sewage System (YDSS) that is co-owned and co-managed by the Regional Municipalities of York and Durham (the Regions).

The system was commissioned on January 27, 2015 and has since been in operation.

The SEC Trunk Sewer Individual Environmental Assessment (IEA) was approved on March 31, 2010 allowing the Regions to proceed with the undertaking subject to 13 Conditions (74 sub-conditions) introduced by the Minister of the Environment's Notice of Approval to Proceed with the Undertaking (Approval).

To address Condition 9 of the Approval, the Odour Management and Mitigation Plan (OMMP) was prepared and submitted to the Ministry of the Environment, Conservation and Parks (MOECP) on September 24, 2010. Subsequently, on December 5, 2014, an updated OMMP was provided to include the Operation Manuals for each of the four main components of the odour control system prior to commissioning. On March 24, 2015, the MOECP provided comments on the updated OMMP. These comments and outcomes from the annual meeting held on May 19, 2015 including all other subsequent MOECP comments have been fully addressed in the Revised Addendum to the updated OMMP dated June, 2016.

To address Condition 11 of the Approval, an Ambient Air Monitoring and Reporting Plan (AAMRP) was submitted to the MOECP on September 2010. The objective of the AAMRP is to confirm the operation of the SEC, and its odour control system and meet the designed performance in respect of emissions as set out in the SEC IEA.

The sampling programs for both Conditions 9 and 11 include sampling for odour, hydrogen sulphide (H₂S), ammonia (NH₃), and total reduced sulphur (TRS) compounds at the same sensitive receptors with the same sampling criteria. In addition, the two programs are to follow the same schedule and sampling frequency, and it was agreed at the May 2015 annual meeting with the MOECP that the annual reports required under each Condition (9 and 11) are to be consolidated into one Annual Report.

This report is the fourth annual report to satisfy Conditions 9.5, 9.6, and 11.5 of the Approval and it will be posted on the york.ca website as per Conditions 9.7 and 11.7 and covers the period July 2017 to June 2018.

As per Condition 9.3 (e) annual meetings with the MOECP Director progressed at the project specific level until 2017 where the decision was made to move the Condition 9 discussion items into the Agenda of regular quarterly liaison meetings between York Region and MOECP at the senior management level.

Conditions 9 and 11 sampling programs are being conducted concurrently in two phases:

- **Phase 1:**
 - a) Pre-Operation - Ambient Monitoring
 - b) Start-up of Operations Ambient Air Monitoring and Air Emission Testing
- **Phase 2:** Post Operation Ambient Air Monitoring and Air Emission Testing

The schedules of sampling are shown on the table below.

Phase	Description	Year	Total Number of Sampling Campaigns	Sampling Seasons	Status
1A	Pre-Operation – Ambient Air Monitoring	2012	3	Spring, Summer, Fall	Complete
		2013	3	Winter, Spring, Summer	Complete
1B	Start-up Operations – Ambient Air Monitoring and Air Emissions Testing	One	3	Spring, Summer, Fall (2015)	Complete
2	Post Operation – Ambient Air Monitoring and Air Emissions Testing	One	3	Spring, Summer, Fall (2015)	Complete
		Two	3	Spring, Summer, Fall (2016)	Complete
		Three	2	Early Spring, Summer (2017)	Complete
		Four	1	Summer (2018)	Ongoing
		Five	1	Summer (2019)	

Odour Management and Mitigation (Conditions 9.5 and 9.6) and Ambient Air Monitoring and Reporting (Condition 11.5)

The sampling program covers the requirements for both Conditions 9 and 11.

Phase 1a, and Phase 1b/Phase 2 Year One:

Conducted between 2012 and 2015 with the results of the campaigns discussed in previous reports.

Phase 2 Year Two:

Conducted in 2016 with the results of the campaigns discussed in previous reports.

Phase 2 Year Three:

Conducted in 2017 with the results of the campaigns discussed in previous reports.

Phase 2 Year Four:

The Phase 2 Year Four sampling is ongoing, with field sampling for Summer 2018 underway.

OCF Technology Performance:

Performance testing of the odour control facility was conducted on January 29, 2018 and April 2, 2018 by the equipment supplier BIOREM Technologies Inc. The results of the testing showed that the media and the system are performing well with no major adjustments required.

Table of Contents

	Page
1. Introduction.....	1
1.1 Summary of Condition 9 and 11 Requirements and Updates.....	1
1.2 Purpose and Objective.....	3
2. Odour Management and Mitigation (Conditions 9.5 and 9.6) and Ambient Air Monitoring and Reporting (Condition 11.5)	4
2.1 Phase 1b / Phase 2 Year One Sampling.....	4
2.2 Phase 2 Year Two Sampling.....	4
2.3 Phase 2 Year Three Sampling	4
2.4 Phase 2 Year Four Sampling	4
2.5 OCF Technology Performance.....	4
2.6 Statement of Accommodation	5

List of Tables

Table 1: Odour Testing Schedule	2
Table 2: Summary of the SEC OCF Media Testing.....	5

1. Introduction

The Southeast Collector (SEC) Trunk Sewer system conveys municipal wastewater 15 kilometres from the intersection of the Ninth Line and Rouge Bank Drive in Markham, Ontario, to the intersection of Finch Avenue and Valley Farm Road in Pickering, Ontario. The operation of the system accommodates the future growth in York Region, and provides additional capacity for peak and extraneous flows. Furthermore, it increases redundancy to the existing York Durham Sewage System (YDSS) that is co-owned and co-managed by the Regional Municipalities of York and Durham (the Regions).

The system is equipped with an odour control system to reduce the creation of odour-containing compounds inside the trunk sewer, limit the corrosion of the sewer headspace/shafts, maintain the trunk sewer headspace under negative pressure, and collect and treat odour emissions before release to the natural environment. The four main components of the odour control system are the Corrosion Control Facility (CCF) at Shaft 13, the Odour Control Facility (OCF) at York-Durham Line, and the Air Handling Facilities (AHF) at Shaft 4 and at Shaft 6/7.

The system was commissioned on January 27, 2015 and has since been in operation.

1.1 Summary of Condition 9 and 11 Requirements and Updates

The SEC Trunk Sewer Individual Environmental Assessment (IEA) was approved on March 31, 2010 allowing the Regions to proceed with the undertaking, subject to 13 Conditions (74 sub-conditions) under the Minister of the Environment's Notice of Approval to Proceed with the Undertaking (Approval).

To address Condition 9 of the Approval, an Odour Management and Mitigation Plan (OMMP) was prepared and submitted to the Ministry of the Environment, Conservation and Parks (MOECP) on September 24, 2010. Subsequently, on December 5, 2014, an updated OMMP was submitted to include the respective Operation Manual for each of the four main components (CCF, OCF, Shaft 4 AHF and Shaft 6/7 AHF) of the odour control system prior to commissioning. On March 24, 2015, the MOECP provided comments on the updated OMMP. These comments and outcomes from the annual meeting held on May 19, 2015 including all other subsequent MOECP comments have been fully addressed in the Revised Addendum to the updated OMMP dated June, 2016.

In addition, to address Condition 11 of the Approval, an Ambient Air Monitoring and Reporting Plan (AAMRP) was submitted to the MOECP in September 2010 with the objective of confirming the operation of the SEC, and its odour control system meet the designed performance in respect of air emissions as set out in the SEC IEA.

The sampling programs for both Conditions 9 and 11 include sampling for odour, hydrogen sulphide (H₂S), ammonia (NH₃), and total reduced sulphur (TRS) compounds at the same sensitive receptors with the same sampling criteria. In addition, the two programs are to follow the same schedule and sampling frequency. The sampling is conducted at the same six sensitive receptor locations identified as part of the Pre-test Plan, 2011.

Condition 9 and 11 sampling programs include the following Phases and are being conducted as per the Schedule shown in Table 1:

- **Phase 1:**
 - a) Pre-Operation – Ambient Monitoring
 - b) Start-up of Operations Ambient Air Monitoring and Air Emission Testing
- **Phase 2:** Post Operation Ambient Air Monitoring and Air Emission Testing

Table 1: Odour Testing Schedule

Phase	Description	Year	Total Number of Sampling Campaigns	Sampling Seasons	Status
1A	Pre-Operation – Ambient Air Monitoring	2012	3	Spring, Summer, Fall	Complete
		2013	3	Winter, Spring, Summer	Complete
1B	Start-up Operations – Ambient Air Monitoring and Air Emissions Testing	One	3	Spring, Summer, Fall (2015)	Complete
2	Post Operation – Ambient Air Monitoring and Air Emissions Testing	One	3	Spring, Summer, Fall (2015)	Complete
		Two	3	Spring, Summer, Fall (2016)	Complete
		Three	2	Early Spring, Summer (2017)	Complete
		Four	1	Summer (2018)	Ongoing
		Five	1	Summer (2019)	

1.2 Purpose and Objective

This report is prepared in accordance with Conditions 9.5, 9.6 and 11.5 of the Approval.

Specifically, Conditions 9.5, and 9.6 state:

9.5 *The proponent shall prepare and submit twice annually to the Director, Regional Director and SeCAC (if applicable), Odour Management and Mitigation Monitoring Reports beginning six months following the commencement of operation of the undertaking.*

9.6 *The proponent shall include in each of the Odour Management and Mitigation Monitoring Reports submitted in accordance with Condition 9.5, a report on the performance of the technology used for odour control at the Odour Control Facility.*

Condition 11.5 states:

11.5 *The proponent shall report the results of the ambient air monitoring program to the Regional Director and SeCAC (if applicable) in accordance with the Ambient Air Monitoring and Reporting Plan.*

The structure of the Report is set-up to follow the above conditions. In addition, the Annual Report will be posted on the york.ca website as per Conditions 9.7 and 11.7.

2. Odour Management and Mitigation (Conditions 9.5 and 9.6) and Ambient Air Monitoring and Reporting (Condition 11.5)

2.1 Phase 1b / Phase 2 Year One Sampling

The Phase 1b/Phase 2 Year One Sampling was conducted in Spring, Summer and Fall 2015 and results were provided in the “Odour Management and Mitigation (Condition 9) and Ambient Air Monitoring and Report (Condition 11) Annual Report” submitted on July, 2016 (Second Annual Report).

2.2 Phase 2 Year Two Sampling

The Phase 2 Year Two Sampling was conducted in Spring, Summer and Fall 2016. The results of the Spring 2016 sampling was provided in the “Odour Management and Mitigation (Condition 9) and Ambient Air Monitoring and Report (Condition 11) Annual Report” submitted on July 2016 (Second Annual Report) and the results of the Summer and Fall 2016 sampling were provided in the “Odour Management and Mitigation (Condition 9) and Ambient Air Monitoring and Report (Condition 11) Annual Report” submitted on July 2017 (Third Annual Report).

2.3 Phase 2 Year Three Sampling

The Phase 2 Year Three sampling was conducted in Early Spring and Summer 2017. The results for both the Spring and Summer sampling were provided in the “Odour Management and Mitigation (Condition 9) Semi-Annual Report” dated January 31, 2018.

2.4 Phase 2 Year Four Sampling

The Phase 2 Year Four sampling is ongoing, with field sampling for Summer 2018 underway.

2.5 OCF Technology Performance

Performance testing of the odour control facility was conducted on January 29, 2018 and April 2, 2018 by the equipment supplier BIOREM Technologies Inc. (BIOREM).

One of the biotrickling filter units has had pH measurements above the desired range during the two testing periods. However, BIOREM noted that the pH will not affect the overall performance of the system and no further action is required at this time but to continue monitoring the system. A minor corrective action was also recommended to adjust the irrigation duration by reducing on-time by 25%.

Moisture of Biofilter and Biotrickling Filter are slightly outside the ‘desired range’, however it was confirmed by BIOREM that those parameters are only “desired” and provide some guidance, where actions should be recommended based on media performance. As a result of media testing, BIOREM confirmed that overall, results of the media testing are showing that the media and the system are performing well without issues.

Table 3 below shows the average results of the samples taken during the date of testing.

Table 2: Summary of the SEC OCF Media Testing

Parameters	Desired Range	January 29, 2018	April 2, 2018
Moisture of Biofilter (%)	20 – 30	35.2 – 38.2	34 – 35.4
Moisture of Biotrickling Filter (%)	50 – 100	87.2 – 146.8	102.4 – 127.6
pH of Biofilter	5 – 9	8.72 – 8.8	8.62 – 8.88
pH of Biotrickling Filter	1 – 4	3.84 – 7.83	3.65 – 7.41
NO ₃ (ppm)	-	<0.5 – 1.0	<0.5 – 3.0
Phosphorus (ppm)	-	<1	<1

2.6 Statement of Accommodation

Accessible formats or communication supports for this report are available upon request. Please contact Environmental Services Reception Desk at 1-877-464-9675 ext. 73000.