



PLANTING SOIL MIX AS SPECIFIED, FINISHED GRADE OF TOPSOIL 50mm BELOW TOP OF WALL

DRAINAGE COMPOSITE

C.I.P. RAISED PLANTER WALL EXPOSED SURFACES TO BE A SMOOTH LIGHT SAND BLAST FINISH

COLOURED CONCRETE SPLASH STRIP OR UNIT PAVERS

50mm KEY

150mm MIN DEPTH GRANULAR 'A', COMPACTED TO 98% S.P.D.

CLASS 1 GEOTEXTILE, NON WOVEN. ALL JOINTS CONNECTED WITH STEEL STAPLES EVERY 1000mm

500mm X 300mm DEPTH 19mm CRUSHED CLEAR STONE

150mm Ø PERFORATED WEEPING TILE, c/w FILTER SOCK

NON-PERFORATED 150mm PVC SUBDRAIN CONNECT TO C.B., M.H. OR SUMP AT LOW END OF MEDIAN.

NOTES:

1. ALL DIMENSIONS IN MILLIMETRES UNLESS OTHERWISE NOTED.
2. CONCRETE FOR PLANTER WALLS SHALL BE 35MPa 5-7% AIR ENTRAINED AT 28 DAYS , EXPOSURE CLASS C-1
3. 10mm PERFORMED JOINT FILLER, TYPE A, NON-EXTRUDING AND RESILIENT BITUMINOUS COLOUR MATCHED POLYSULFIDE SEALANT FOR ALL EXPANSION JOINTS.
4. ALL EXPOSED CONCRETE SURFACES TO BE A SMOOTH FINISH.
6. CONNECT SUBDRAIN TO POSITIVE DRAINAGE I.E. STORM, CATCH BASIN MANHOLE EVERY 3 PLANTERS MAXIMUM.



Transportation
Services

**CAST-IN-PLACE MEDIAN
PLANTER LAYOUT I**

DATE: JANUARY 2020 SCALE N.T.S.

REV. X X SS-200B