



NOTES

1. ALL DIMENSIONS ARE IN MILLIMETERS UNLESS OTHERWISE NOTED.
2. SLOPE OF RAMP SHALL NOT EXCEED 10%.
3. CROSS SLOPE OF RAMP SHALL NOT EXCEED 2% IN EITHER DIRECTION.
4. CROSS SLOPE OF FLARED SIDE OF RAMP SHALL NOT EXCEED 10%.
5. DROPPED CURB AT RAMP SHALL BE MODIFIED TO ELIMINATE 30mm STEP AT GUTTER LINE.
6. MINIMUM THICKNESS OF RAMP IS 200mm. MINIMUM THICKNESS OF SIDEWALK AND FLARED SIDES ADJACENT TO RAMP IS 150mm.
7. TACTILE WARNING PLATES SHOULD EXTEND THE WIDTH OF THE DROPPED CURB RAMP.
8. SEE STANDARD DRAWING DS-408 FOR FULL INTERSECTION LAYOUT.
9. ACCESSIBLE PEDESTRIAN SIGNAL POLE FOR SIGNALIZED INTERSECTIONS ONLY.
10. JOINTS MUST NOT BE TROWELLED.

Transportation Services			
<h2 style="margin: 0;">CONCRETE SIDEWALK RAMPS AT INTERSECTIONS</h2>			
DATE: DECEMBER 2016	SCALE N.T.S.		
REV.	X	X	DS-121