



UNIT PAVING AS SPECIFIED - REFER TO PAVING LAYOUT DRAWINGS FOR PAVER TYPE AND PATTERN

No. 8 JOINTING STONE AS PER ASTM D448

SOD

CONCRETE EDGE RESTRAINT

150mm OFFSET FROM EDGE RESTRAINT

50mm No. 8 BEDDING STONE AS PER ASTM D448

300mm GRANULAR 'O' COMPACTED TO 98% S.P.D.

CLASS 1 GEOTEXTILE, NON WOVEN. ALL JOINTS CONNECTED WITH STEEL LANDSCAPE STAPLES EVERY 1000mm

SUBGRADE COMPACTED TO 98% SPD, 2% SLOPE TO ALL CURB SUBDRAINS (TYP).

GRANULAR BASE TO CONNECT TO ROAD CURB GRANULAR

**NOTES:**

1. ALL DIMENSIONS IN MILLIMETRES UNLESS OTHERWISE NOTED
2. JOINTING STONE TO BE APPLIED FLUSH WITH TOP OF PAVERS
3. ALL JOINTING, BEDDING, AND SUBBASE TO BE CLEAR ANGULAR STONE WITH NO ROUNDS.
4. PAVER JOINT OR OPENING FILL AGGREGATE SHALL USE NO. 8 MATERIAL AS DESCRIBED ABOVE, SMALLER AGGREGATE (NO. 89, 9 OR 10, PER ASTM D448) MAY BE SUBSTITUTED IF REQUIRED TO FILL NARROWER JOINTS OR OPENINGS.



Transportation Services

**PERMEABLE UNIT PAVERS**

DATE: JANUARY 2020

SCALE N.T.S.

REV.

X

X

SS-101B