

# 2019 Annual Drinking Water System Quality Report for Kleinburg DWS

Prepared by The Regional Municipality of York pursuant to Section 11 of O.Reg. 170/03

**Drinking Water System Number:** 220002360  
**Drinking Water System Name:** Kleinburg DWS  
**Drinking Water System Owner:** The Regional Municipality of York  
**Drinking Water System Category:** Large Municipal Residential  
**Drinking Water System Classification:** Water Distribution and Supply II  
**Reporting period:** Jan 1, 2019 - Dec 31, 2019

## **The Kleinburg DWS serves approximately 7,670 people**

(Population is a year-end forecasted estimate based on Statistics Canada census data, and building permits)

## **List all Drinking Water Systems which receive their drinking water from the Kleinburg DWS:**

Vaughan Distribution System (260003097)

This annual report is available to the public at no charge on the Region's website ([york.ca/drinkingwater](http://york.ca/drinkingwater)) and upon request. Accessible formats or communication supports are also available upon request. Please contact [AccessYork@york.ca](mailto:AccessYork@york.ca) or call 1-877-464-9675.

**A copy of York Region's annual report was provided to all Drinking Water System owners that are connected to and receive drinking water from York Region.**

**System users were notified that York Region's annual report is available free of charge by public access and notice through:**

- Media (internet, social media)
- Public requests at any time

**Summary report required under O.Reg. 170/03 Schedule 22 will be available for inspection at:**

The Regional Municipality of York  
Administrative Centre  
Environmental Services Department  
17250 Yonge Street, Newmarket ON

## **Description of the Kleinburg DWS**

### **Introduction**

Kleinburg is a village in the City of Vaughan. Kleinburg DWS provides water from Lake Ontario through the York DWS. Two wells are maintained as an emergency backup water source. York Region operates the water supply, and the City of Vaughan maintains and distributes water to users. The Province governs the Region's operations with Acts and Regulations, a Permit to Take Water, a Municipal Drinking Water License and an operating Permit. Lake Ontario water is purchased with supply agreements.

### **Raw water source**

Groundwater

### **Profile of water in distribution system**

Blended - Lake and Groundwater

### **Water treatment description**

Kleinburg DWS includes two wells, one storage facility and two booster pumping stations. Chlorine provides disinfection, and chloramine provides a secondary residual. Sodium silicate is added to sequester naturally occurring iron and manganese. The storage facility holds treated water and helps the booster stations maintain pressure. Operators test the water and inspect the process. Online analyzers continuously monitor treatment and water flow. When analyzers detect a significant process or water quality issue, the system automatically pauses operation until an operator takes action.

### **List of water treatment chemicals used in this system**

In 2019, water in Kleinburg came pre-treated from the York DWS. Well facilities were not run for supply, but can apply chlorine (gas) and ammonia solution for chloramination, and sodium silicate. Treatment systems and well performance are tested regularly in case they are ever needed for backup capacity.

### **Brief description and breakdown of monetary expenses incurred**

\$23,005 for general maintenance and repairs.

**Notices submitted under Section 18(1) of the Safe Drinking Water Act or Section 16-4 of O.Reg. 170/03 and reported to MECP Spills Action Centre**

Adverse Parameter	Incident Date	Adverse Test Result	Corrective Action	Corrective Action Date
Chlorine Residual	30-Sep-19	4.05 mg/L	Operator attended site, restored facility to normal operation. Compliant grab sample taken.	02-Oct-19

**Microbiological testing completed under Schedule 10 of O.Reg. 170/03**

\*For additional distribution samples collected under Schedule 10, refer to the local municipality

Test Parameter	Sample Source	Count Of Samples	Count Of Presence
E. coli	Raw	106	0
Total Coliforms	Raw	106	0

**Operational testing completed under Schedule 7 of Regulation 170/03 during this reporting period**

\*8,760 is used as the number of samples for continuous analyzers

Test Parameter (group)	Test Units	No. of Samples	Average	Minimum	Maximum
Combined Chlorine	mg/L	8,760	1.81	0.05	3.94
Turbidity (Treated)	NTU	8,760	0.05	0.01	5.00

**Summary of testing pursuant to Schedule 13 of O. Reg. 170/03 and sampling carried out in accordance with the requirement of an approval, order or other legal instrument**

Values with a less than sign (" $<$ ") indicate that the test result is below the method detection limit from the accredited laboratory (i.e. non-detect). Average results include values which were returned as non-detect and are rounded to three decimals. For a complete set of results, see the open dataset available at [york.ca/drinkingwater](http://york.ca/drinkingwater)

Test Parameter	Test Units	No. of Samples	Average	Minimum	Maximum
Fluoride	mg/L	4	0.635	0.57	0.69
Haloacetic Acids	mg/L	4	0.008	<0.008	0.0098
Nitrate	mg/L	4	0.525	<0.5	0.6
Nitrite	mg/L	4	0.050	<0.05	<0.05
Sodium	mg/L	1	21.800	21.8	21.8
Trihalomethanes	mg/L	4	0.020	0.0149	0.0288

\*Lead testing under Schedule 15.1 is conducted by the Local Municipality - refer to Local Municipality reports for results. York Region occasionally collects samples tested for lead for non-regulatory research purposes

## Organic and inorganic parameter(s) that exceeded half the standard prescribed in Schedule 2 of O.Reg. 169/03 Ontario Drinking Water Quality Standards

### Not Applicable

There were no parameters that exceeded half the standard indicated above for the Kleinburg DWS during 2019

### Summary of inorganic parameters tested pursuant to Schedule 23 of O.Reg. 170/03

Values with a less than sign (" $<$ ") indicate that the test result is below the method detection limit from the accredited laboratory (i.e. non-detect). Average results include values which were returned as non-detect and are rounded to five decimals. For a complete set of results, see the open dataset available at [york.ca/drinkingwater](http://york.ca/drinkingwater)

Test Parameter	No. of Samples	Test Units	Average	Minimum	Maximum	ODWS Limit
Antimony	1	mg/L	0.00070	0.0007	0.0007	0.006
Arsenic	1	mg/L	0.00050	<0.0005	<0.0005	0.01
Barium	1	mg/L	0.26500	0.265	0.265	1
Boron	1	mg/L	0.11500	0.115	0.115	5
Cadmium	1	mg/L	0.00050	<0.0005	<0.0005	0.005
Chromium	1	mg/L	0.00050	<0.0005	<0.0005	0.05
Mercury	1	mg/L	0.00005	<0.00005	<0.00005	0.001
Selenium	1	mg/L	0.00050	<0.0005	<0.0005	0.05
Uranium	1	mg/L	0.00050	<0.0005	<0.0005	0.02

**Summary of organic parameters tested pursuant to Schedule 24 of O.Reg. 170/03**

Values with a less than sign (“<”) indicate that the test result is below the method detection limit from the accredited laboratory (i.e. non-detect). Average results include values which were returned as non-detect and are rounded to four decimals. For a complete set of results, see the open dataset available at [york.ca/drinkingwater](http://york.ca/drinkingwater)

**Not Applicable**

No organic parameters were tested for the Kleinburg DWS as the wells are non-operational.